

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 1400
Room Name	Bay - Mobile Equipment, 6m2	Room Code: BMEQ-6
Area	6.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	N/A	
Also covers these Rooms		
Description/ Special Requirements	<p>An open storage bay for one or more items of mobile equipment in frequent use which may include mobile X-ray equipment, wheelchairs, mobile scales, commode chairs, patient lifting devices, or other mobile equipment.</p> <p>Special Design Requirements: The Bay should be deep enough to ensure equipment stored does not impede corridor circulation; minimum depth 1000mm.</p> <p>Electrical equipment that requires recharging may be stored in this space whilst recharging, therefore provision of appropriately located power outlets will be required.</p>	
Amendment	31.10.03, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to 'Acrovyn'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		Equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
7400	Trolley: equipment	Furniture/ Fitting	3	1	as required
24200	Wheelchair	Furniture/ Fitting	3	2	as required

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
35700	IMG: X-ray machine, mobile	3	1	yes	—	—	—	—	—	—	—	parking area

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		

Australasian Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Bay - Mobile Equipment, 6m2**

Room Tag: 1400
Room Code: BMEQ-6

ID	Description	Service Category	Qty	Remarks
9001	GPO: Double	Power	2	For recharging of electrical equipment