

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 1600
Room Name	Clean-Up Room - Shared, 15 m2	Room Code: CLUP-15
Area	15.0 M2	
No of Rooms	1	
Subtotal of Area	15.0 M2	
Minimum Dimension	0.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 - 2	
Also covers these Rooms		
Description/ Special Requirements	The Clean-Up Room, Shared is used for rinsing and cleaning of medical equipment or endoscopes used in the Operating Rooms or Procedure Rooms. Low temperature sterilisation of endoscopes may also be undertaken in this room. The shared Clean-up Room should be located between two Minor Operating Rooms or Procedures rooms where endoscopy procedures are undertaken.	
Amendment	10.10.03, - First Draft 22.03.05, - BOB User review, cupboards modified, sinks & Gr 3FFE modified	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		1100 mm clear opening to ORs, double swing, sliding cover to observation panel
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	for tube drying
1010	Bench: stainless steel	Metalwork	1	2	with wet edge, 1 with inset sinks
4430	Cupboard: drawer unit	Furniture/ Fitting	1	1	under dry bench
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over dry bench
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin

Australasian Standard Project

Room Data Sheets

Department **Standard Components**
 Room Name **Clean-Up Room - Shared, 15 m2**

Room Tag: **1600**
 Room Code: **CLUP-15**

ID	Description	Category	Group	Qty	Selection
19810	Shelf: SS, over bench	Metalwork	1	1	over sink bench
19820	Shelf: SS, under bench	Metalwork	1	1	under sink bench
21950	Suction adapter	Furniture/ Fitting	3	1	for tube cleaning
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	
49100	Sink: 750x500x300D	1	1	___	___	yes	opt	opt	yes	yes	___	hot water
49800	Sink: flushing rim	1	1	___	___	yes	___	___	___	yes	___	in bench
52450	Steriliser: low temperature, peracetic acid	3	1	yes	___	yes	yes	___	___	yes	___	optional

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		efficient exhaust required
4010	Cold water: manifold	Hydraulics	1	for low temp steriliser, optional
4033	Floor waste	Hydraulics	1	
4000	Hot water: manifold	Hydraulics	1	for low temp steriliser, optional
4037	Tundish drain	Hydraulics	1	for low temp steriliser, optional
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting	1	under O/H cupboards
7020	Medical Air (MA)	Medical Gases	1	over dry bench for tube drying
7040	Suction	Medical Gases	1	near sink for tube cleaning
9001	GPO: Double	Power	1	
9011	GPO: Emergency power, double	Power	1	
9060	Special: for equipment	Power	1	optional, for low temp steriliser