

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 1860
Room Name	Disposal Room, 8m2	Room Code: DISP- 8
Area	8.0 M2	
No of Rooms	1	
Subtotal of Area	8.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 - 2 intermittently	
Also covers these Rooms		
Description/ Special Requirements	<p>The Disposal Room provides for the temporary holding of clinical waste, general waste, sharps, soiled linen and recyclables prior to removal. The Disposal Room should include a handwashing basin within the room if waste will be handled in this area.</p> <p>The room should be lockable.</p>	
Amendment	10.10.03, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5030	Ceiling	Plasterboard	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9001	Doors	Solid Core	Paint	Single leaf		910mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3040	Wall finish	Vinyl	Prefinished	Wall vinyl to 1200 AFFL		
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin, if provided
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		as required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin, if provided
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin, if provided
24125	Waste bin: clinical	Furniture/ Fitting	3	1	240 Litre
24102	Waste bin: general	Furniture/ Fitting	3	2	240 Litre
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin, if provided

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2850	Basin: handwash, Type C	1	1	—	—	yes	—	yes	yes	yes	—	optional, refer to BHWS-C (sim)

Australasian Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Disposal Room, 8m2**

Room Tag: 1860
Room Code: DISP- 8

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
6000	General fluorescent	Lighting		