

# Australasian Standard Project

## Room Data Sheets

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 2480</b>
<b>Room Name</b>	<b>Office - Write-Up (Shared)</b>	<b>Room Code: OFF-WIS</b>
<b>Area</b>	12.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	12.0 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	Up to 4	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	A shared office located close to the Staff Station for staff to review and write up notes, view X-rays or digital imaging, enter patient data on computer, make telephone calls and store records.	
	Acoustics: Sound attenuation level - Medium; acoustic privacy required.	
<b>Amendment</b>	28.01.04, - First Draft 08.02.05, - BOB User review, unchanged	

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		
9002	Doors	Solid Core	Paint	Single leaf, half glazed		910mm clear opening, door optional
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.		vinyl also acceptable
7030	Observation	Alum/ glass	Powdercoat	Internal window, door height		optional
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH		or floor vinyl covered skirting
3000	Wall finish	Paint	Acrylic, washable			

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	2	
1562	Cabinet: X-Ray slots	Furniture/ Fitting	1	2	under benches
2100	Chair: ergonomic, office	Furniture/ Fitting	3	4	
17360	Pinboard: fabric covered	Furniture/ Fitting	1	2	above benches
20000	Shelving unit: adjustable	Furniture/ Fitting	1	2	over benches, full length
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	2	

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
11400	Computer: PC & monitor	3	2	yes	yes	___	___	___	___	___	___	optional
41100	Printer: networked	3	1	yes	yes	___	___	___	___	___	___	optional
54510	Telephone: handset, standard	3	2	___	yes	___	___	___	___	___	___	
68900	Xray viewer: 4 screen	1	1	yes	___	___	___	___	___	___	___	recessed

**Australasian Standard Project**  
**Room Data Sheets**

**Department** | **Standard Components**  
**Room Name** | **Office - Write-Up (Shared)**

**Room Tag:** 2480  
**Room Code:** OFF-WIS

**Services**

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	4	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelves
8040	Annunciator	Nurse Call		to be audible in this room
9001	GPO: Double	Power	9	2 per workstation + 1
9060	Special: for equipment	Power	1	Xray viewer