

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 2910
Room Name	Shower - Patient	Room Code: SHPT
Area	4.0 M2	
No of Rooms	1	
Subtotal of Area	4.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 patient; 1-2 staff assisting as required	
Also covers these Rooms		
Description/ Special Requirements	<p>The Shower - Patient is a room containing a shower and a handbasin for patients in multi-bed rooms to shower or wash, either independently or with nurse assistance.</p> <p>Acoustics: Sound attenuation level - high; Acoustic privacy required.</p> <p>Body Protected electrical area</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> - Access is required for commode chairs - The floor must not have a raised hob - The door will require escape hardware to allow staff access in an emergency 	
Amendment	11.12.03, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9001	Doors	Solid Core	Paint	Single leaf		910mm clear; outward opening; privacy latch; emergency release
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved		tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or tiles for tiled floor
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height		to wet areas; tiles also acceptable
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
530	Basin vanity top	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	2	1 @ 1200H for wheelchair users
4800	Curtain track: shower	Metalwork	1	1	
5300	Curtain: shower	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	optional

Australasian Standard Project

Room Data Sheets

Department **Standard Components**
 Room Name **Shower - Patient**

Room Tag: **2910**
 Room Code: **SHPT**

ID	Description	Category	Group	Qty	Selection
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
8450	Grab rail: Shower	Metalwork	1	1	
9200	Hook: for catheter bag	Metalwork	1	1	
10800	Hook: for IV flasks	Metalwork	1	1	
13700	Mirror	Metalwork	1	1	
20650	Soap/ shampoo holder	Furniture/ Fitting	1	1	
23700	Towel rail	Metalwork	1	1	with grab rail strength/ fixings
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3120	Basin: vanity	1	1	___	___	yes	___	yes	yes	yes	___	
47400	Shower: hand-held	1	1	___	___	yes	___	yes	yes	yes	___	

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light, waterproof
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light, waterproof
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light, waterproof
9040	Body protected	Power		
9001	GPO: Double	Power	1	