

# Australasian Standard Project

## Room Data Sheets

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 3180</b>
<b>Room Name</b>	<b>Toilet - Patient</b>	<b>Room Code: WCPT</b>
<b>Area</b>	4.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	4.0 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 patient; 1 staff assisting as required	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>Room containing a toilet and handbasin for patients in multi-bed rooms or adjacent to communal patient areas. The door will be fitted with escape hardware to allow staff access in an emergency.</p> <p>Acoustics: Sound attenuation level - High. Acoustic privacy required.</p> <p>Body protected electrical area</p>	
<b>Amendment</b>	<p>08.12.03, - First Draft</p> <p>09.02.05, - BOB User review, fittings modified</p>	

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn; both sides
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn; both sides
9001	Doors	Solid Core	Paint	Single leaf		910mm clear outward opening, privacy latch, emergency release
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or tiles for tiled floor
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		tiles also acceptable

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
530	Basin vanity top	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	2	1 @ 1200 AFFL for wheelchair users
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	optional
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6160	Dispenser: toilet paper	Furniture/ Fitting	2	1	
8400	Grab rail: WC	Metalwork	1	2	1 behind toilet, 1 to side
9200	Hook: for catheter bag	Metalwork	1	1	
10800	Hook: for IV flasks	Metalwork	1	1	

# Australasian Standard Project

## Room Data Sheets

Department **Standard Components**  
 Room Name **Toilet - Patient**

Room Tag: **3180**  
 Room Code: **WCPT**

ID	Description	Category	Group	Qty	Selection
13700	Mirror	Metalwork	1	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3120	Basin: vanity	1	1	___	___	yes	___	yes	yes	yes	___	
55605	Toilet suite: patient	1	1	___	___	yes	___	___	yes	yes	___	

### Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	1	