

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 2050
Room Name	Consult Room - ENT/ Ophthalmology	Room Code: CONS-ENT-OP
Area	12.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 patient; 1-2 staff and on occasions an escort/ interpreter	
Also covers these Rooms		
Description/ Special Requirements	<p>The Consult Room ENT/ Ophthalmology will provide for private consultation and examination of patients for ENT/ Ophthalmology using specialised equipment. The Consult room may also be used for general consultations.</p> <p>Acoustics: Sound attenuation level - high; Acoustic privacy essential.</p> <p>Body Protected electrical area</p>	
Amendment	<p>24.01.05, - First Draft 01.03.05, - BOB user review, door modified</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		flush ser plasterboard ceiling also acceptable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or vinyl featheredge skirting over carpet
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1470	Bracket: sharps	Furniture/ Fitting	2	1	
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
2600	Chair: visitor, office	Furniture/ Fitting	3	3	
3400	Coathook	Metalwork	1	2	
4600	Curtain track: bed screen	Metalwork	1	1	to exam couch
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
5900	Desk	Furniture/ Fitting	3	1	
6140	Diagnostic set: portable	Furniture/ Fitting	3	1	optional
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin

NSW Standard Project

Room Data Sheets

Department **Standard Components**
 Room Name **Consult Room - ENT/ Ophthalmology**

Room Tag: **2050**
 Room Code: **CONS-ENT-OP**

ID	Description	Category	Group	Qty	Selection
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to hand basin
7500	Examination couch	Furniture/ Fitting	3	1	
8100	Footstool	Furniture/ Fitting	3	1	
13725	Mirror: hinged	Metalwork	3	1	wall mounted, for eye chart
19700	Sharps bin	Furniture/ Fitting	3	1	Wall mounted
21030	Sphygmomanometer: wall mounted	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-B (sim)
36910	Light box: optical	3	1	yes	___	___	___	___	___	___	___	Snellen eye chart light box
31701	Light: examination, wall mount	1	1	yes	___	___	___	___	___	___	___	or ceiling mounted, optional
44360	Refrigerator: drugs, small	3	1	yes	opt	___	___	___	___	___	___	eye medications
50600	Slit lamp	3	1	yes	___	___	___	___	___	___	___	
54520	Telephone: handset, handsfree	3	1	___	yes	___	___	___	___	___	___	to desk
68700	Xray viewer: 2 screen	1	1	yes	___	___	___	___	___	___	___	

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	as required
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	1	patient examination area
9001	GPO: Double	Power	2	workstation / desk area
9011	GPO: Emergency power, double	Power	1	patient examination area
9000	GPO: Single	Power	4	Fridge, XRV, light box, slit lamp
9060	GPO: Special: for equipment	Power	1	exam light
10005	Duress alarm	Security	1	