

**NSW Standard Project**  
**Room Data Sheets**

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 3200</b>
<b>Room Name</b>	<b>Office - Consult</b>	<b>Room Code: OFF-CON</b>
<b>Area</b>	12.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>		
<b>Hours of Operation</b>	8am to 6pm	
<b>Occupancy</b>	1 patient, 1-2 staff and on occasions support person and interpreter	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>A room where clinical consultation and administrative functions are combined, and may be used by medical, nursing and allied health staff.</p> <p>Acoustics: Sound attenuation level - high; Acoustic privacy required.</p> <p>Body Protected Electrical Area</p>	
<b>Amendment</b>	<p>24.01.05, - First Draft</p> <p>08.02.05, - BOB User review, door modified</p>	

**Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		flush set plasterboard ceiling also acceptable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		910/1400mm clear opening, half leaf optional, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or featheredge skirting over carpet
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		tiles also acceptable

**Fittings and Furniture (FF)**

ID	Description	Category	Group	Qty	Selection
1470	Bracket: sharps	Furniture/ Fitting	2	1	wall mounted
2600	Chair: visitor, office	Furniture/ Fitting	3	3	
3400	Coathook	Metalwork	1	2	
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6140	Diagnostic set: portable	Furniture/ Fitting	3	1	optional
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to hand basin
7500	Examination couch	Furniture/ Fitting	3	1	

# NSW Standard Project

## Room Data Sheets

Department **Standard Components**  
 Room Name **Office - Consult**

Room Tag: **3200**  
 Room Code: **OFF-CON**

ID	Description	Category	Group	Qty	Selection
8100	Footstool	Furniture/ Fitting	3	1	
13700	Mirror	Metalwork	1	1	
17255	Pedestal filing unit: mobile, 660mmH	Furniture/ Fitting	3	1	lockable, under workstation
17360	Pinboard: fabric covered	Furniture/ Fitting	1	1	
19700	Sharps bin	Furniture/ Fitting	3	1	
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over workstation
21030	Sphygmomanometer: wall mounted	Furniture/ Fitting	3	1	
24102	Waste bin: general	Furniture/ Fitting	3	1	
24440	Workstation: computer	Furniture/ Fitting	3	1	

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-B (sim)
11400	Computer: PC & monitor	3	1	yes	yes	___	___	___	___	___	___	to workstation
31701	Light: examination, wall mount	1	1	yes	___	___	___	___	___	___	___	
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	
68600	Xray viewer: 1 screen	1	1	yes	___	___	___	___	___	___	___	above workstation, optional

### Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelving
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	as required
9001	GPO: Double	Power	3	1-patient exam area; 2-workstation
9011	GPO: Emergency power, double	Power	1	patient examination area
9000	GPO: Single	Power	1	X-ray viewer
9060	GPO: Special: for equipment	Power	1	exam light
10005	Duress alarm	Security	1	