

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 3950
Room Name	Specimen Collection Bay, 9m2	Room Code: SPECC
Area	9.0 M2	
No of Rooms	1	
Subtotal of Area	9.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 patient; 1 staff member	
Also covers these Rooms		
Description/ Special Requirements	A Patient Bay used for collection of specimens from patients. The Specimen Collection Bay will have close access to a staff handwashing basin.	
Amendment	Body Protected electrical area 14.03.05, - First Draft 21.03.05, - BOB user review, bench added	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		plasterboard drop in tile ceiling also acceptable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to 'Acrovy'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		Equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1110	Bench: laminate, writing	Furniture/ Fitting	1	1	small, 900mm high
1470	Bracket: sharps	Furniture/ Fitting	3	1	on trolley
2200	Chair: recliner	Furniture/ Fitting	3	1	or mobile trolley/ bed
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
12900	Louvred panel: for storage-bins	Metalwork	1	1	
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
21680	Stool: adjustable, mobile	Furniture/ Fitting	3	1	staff use
21755	Storage bins	Furniture/ Fitting	3	3	for louvred panel

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
31700	Light: examination, ceiling	1	1	yes	—	—	—	—	—	—	—	

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Specimen Collection Bay, 9m2**

Room Tag: 3950
Room Code: SPECC

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6030	Special: downlights	Lighting		over chair
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	as required
9010	GPO: Emergency power, single	Power	1	
9000	GPO: Single	Power	1	