

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 4530
Room Name	Store - Sterile Stock, 20m2 (CSSU)	Room Code: STSS-20
Area	20.0 M2	
No of Rooms	1	
Subtotal of Area	20.0 M2	
Hours of Operation	8am to 8 pm daily	
Occupancy	Up to 3 intermittently	
Also covers these Rooms		
Description/ Special Requirements	An area for storage and holding of sterile stock within the Sterile Supply Unit prior to despatch to the Operating Unit or other patient treatment areas. The area may include a workstation bench as required.	
Amendment	17.02.05, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5020	Ceiling	Plasterboard	Paint, scrub resistant	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to 'Acrovyn'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		Equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1120	Bench: workstation	Furniture/ Fitting	1	1	optional, at 900mm AFFL
1950	Chair: ergonomic, high	Furniture/ Fitting	3	1	to bench, if provided
3350	Clock: battery operated	Furniture/ Fitting	3	1	
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench, optional
19940	Shelving: stainless steel, mobile	Furniture/ Fitting	3	10	dust free
23950	Trolley	Furniture/ Fitting	3	2	
24400	Whiteboard	Furniture/ Fitting	2	1	optional

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	to bench, optional

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5005	Air conditioning: special	HVAC		HEPA filtered

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Store - Sterile Stock, 20m2 (CSSU)**

Room Tag: 4530
Room Code: STSS-20

ID	Description	Service Category	Qty	Remarks
5040	Pressure: positive	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards, if provided
9001	GPO: Double	Power	2	to workstation