

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 4550
Room Name	Store - Sterile Stock, 44m2	Room Code: STSS-44
Area	44.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 - 2 intermittently	
Also covers these Rooms		
Description/ Special Requirements	A room for storage and holding of sterile stock for use in the Operating Suite or other treatment areas. This area may incorporate a workstation and accommodate drugs in lockable cupboards and safe as required.	
Amendment	24.01.05, - First Draft 22.03.05, - BOB User review, Gr 3 fittings modified	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5020	Ceiling	Plasterboard	Paint, scrub resistant	Flush set, suspended		
6015	Cornice	Plasterboard	Paint	Flush coved between wall & ceiling		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3010	Wall finish	Paint	Scrub resistant			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to Acrovyn
7001	Windows					desirable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	1	workstation, optional
1950	Chair: ergonomic, high	Furniture/ Fitting	3	1	to workstation bench, optional
3350	Clock: battery operated	Furniture/ Fitting	3	1	
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, optional
19940	Shelving: stainless steel, mobile	Furniture/ Fitting	3	33	dust free
10200	Trolley: instrument	Furniture/ Fitting	3	3	
24400	Whiteboard	Furniture/ Fitting	2	1	optional

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	to bench

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Store - Sterile Stock, 44m2**

Room Tag: 4550
Room Code: STSS-44

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5005	Air conditioning: special	HVAC		HEPA filtered
5040	Pressure: positive	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards, if provided
9001	GPO: Double	Power	3	