

NSW Standard Project
Room Data Sheets

| | | |
|--|--|------------------------|
| Department | Standard Components | Room Tag: 4680 |
| Room Name | Ultrasound | Room Code: ULTR |
| Area | 14.0 M2 | |
| No of Rooms | 1 | |
| Subtotal of Area | 14.0 M2 | |
| Hours of Operation | Available 24 Hours | |
| Occupancy | 1 patient with up to 1 support person; 1-2 staff | |
| Also covers these Rooms | | |
| Description/ Special Requirements | Room for diagnostic ultrasound procedures, located close to patient toilet and change rooms. The room will require access for patients on hospital beds. | |
| | Acoustics: Acoustic privacy required | |
| | Body Protected electrical area | |
| Amendment | 14.03.05, - First Draft 20.04.05, - BOB User review, room area & fittings modified | |

Room Fabric and outline specifications

| ID | Fabric | Material | Finish | Specification | Selection | Remarks |
|------|-----------------|------------|-------------------------|------------------------------|-----------|--|
| 5060 | Ceiling | Acoustic | Prefinished | Drop-in tiles, 600x1200 | | flush set plasterboard ceiling also acceptable |
| 6030 | Cornice | Aluminium | Powdercoat | 24mm shadow angle | | |
| 8010 | Door protection | Composite | Prefinished PVC | Protection plate to 900 AFFL | | Equal to 'Acrovyn' |
| 8040 | Door protection | Composite | Prefinished PVC | To door frame | | Equal to 'Acrovyn' |
| 9110 | Doors | Solid Core | Paint | 1 1/2 leaf | | 1400mm clear opening |
| 1000 | Floor finish | Vinyl | Standard slip resistant | Seamless, coved | | |
| 2000 | Skirting | Vinyl | Prefinished | Floor vinyl coved, 150 mmH | | |
| 3000 | Wall finish | Paint | Acrylic, washable | | | |
| 3060 | Wall finish | Vinyl | Prefinished | Splashback | | to basin |

Fittings and Furniture (FF)

| ID | Description | Category | Group | Qty | Selection |
|-------|--------------------------------------|--------------------|-------|-----|------------------------------------|
| 1050 | Bench: laminate | Furniture/ Fitting | 1 | 1 | at 1000H, open under part |
| 23400 | Bracket: television, ceiling | Metalwork | 1 | 1 | |
| 2100 | Chair: ergonomic, office | Furniture/ Fitting | 3 | 1 | |
| 2600 | Chair: visitor, office | Furniture/ Fitting | 3 | 2 | optional |
| 3350 | Clock: battery operated | Furniture/ Fitting | 3 | 1 | |
| 3400 | Coathook | Metalwork | 1 | 1 | |
| 4345 | Cupboard: sliding doors, adj shelves | Furniture/ Fitting | 3 | 1 | lockable, optional |
| 4410 | Cupboard: under bench | Furniture/ Fitting | 1 | 1 | under part bench, adjustable shelf |
| 4460 | Cupboard: wall mounted | Furniture/ Fitting | 1 | 1 | over bench, adjustable shelves |
| 4700 | Curtain track: privacy screen | Metalwork | 1 | 1 | to entry door |
| 5250 | Curtain: privacy screen | Furniture/ Fitting | 3 | 1 | to entry door |

NSW Standard Project

Room Data Sheets

Department **Standard Components**
 Room Name **Ultrasound**

Room Tag: **4680**
 Room Code: **ULTR**

| ID | Description | Category | Group | Qty | Selection |
|-------|------------------------------|--------------------|-------|-----|-------------|
| 6152 | Dispenser: disposable glove | Furniture/ Fitting | 2 | 1 | |
| 6154 | Dispenser: paper/ hand towel | Furniture/ Fitting | 2 | 1 | to basin |
| 6156 | Dispenser: soap | Furniture/ Fitting | 2 | 1 | to basin |
| 6158 | Dispenser: soap antiseptic | Furniture/ Fitting | 2 | 1 | to basin |
| 7500 | Examination couch | Furniture/ Fitting | 3 | 1 | mobile |
| 8100 | Footstool | Furniture/ Fitting | 3 | 1 | |
| 18445 | Rack: scanhead storage | Furniture/ Fitting | 3 | 1 | |
| 23950 | Trolley | Furniture/ Fitting | 3 | 1 | under bench |
| 24100 | Waste bin: paper, 20 Litre | Furniture/ Fitting | 3 | 1 | to basin |

Fixtures, Equipment and associated Services (FE)

| ID | Description | Group | Qty | Ele | Data | CdW | HtW | WmW | Tap | Dns | Gas | Selection |
|-------|-------------------------------|-------|-----|-----|------|-----|-----|-----|-----|-----|-----|-----------------------|
| 2800 | Basin: handwash, Type B | 1 | 1 | ___ | ___ | yes | ___ | yes | yes | yes | ___ | refer to BHWS-B (sim) |
| 57800 | IMG: Ultrasound scanning unit | 3 | 1 | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | |
| 54510 | Telephone: handset, standard | 3 | 1 | ___ | yes | ___ | ___ | ___ | ___ | ___ | ___ | |
| 54550 | Television: 34 cm | 3 | 1 | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | ceiling mounted |

Services

| ID | Description | Service Category | Qty | Remarks |
|------|-----------------------------|------------------|-----|---------------------------------|
| 1006 | Voice / Data outlet: double | Communications | 2 | |
| 5000 | Airconditioning | HVAC | | |
| 6110 | Downlights: dimmable | Lighting | | |
| 6000 | General fluorescent | Lighting | | |
| 8080 | Emergency call | Nurse Call | 1 | + indicator button & light |
| 8005 | Patient call handset | Nurse Call | 1 | call button on the handset |
| 8000 | Patient/ Staff call | Nurse Call | 1 | + indicator button & light |
| 8010 | Staff/ Nurse assist call | Nurse Call | 1 | + indicator button & light |
| 9040 | Body protected | Power | | |
| 9015 | GPO: Cleaner | Power | 1 | as required |
| 9001 | GPO: Double | Power | 3 | 2 - staff workstation; 1- bench |
| 9000 | GPO: Single | Power | 2 | exam couch |
| 9060 | GPO: Special: for equipment | Power | 1 | Ultrasound machine |