

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 4730
Room Name	Waiting - 25m2	Room Code: WAIT-25
Area	25.0 M2	
No of Rooms	1	
Subtotal of Area	25.0 M2	
Hours of Operation	24 Hours	
Occupancy	Up to 20	
Also covers these Rooms		
Description/ Special Requirements	An area for visitors and patients to wait in comfort prior to or during visits to a Unit. A Waiting area may be for the use of public, patients, families and other visitors to a facility. The Waiting area will require facilities for a range of occupants including adults and children, both able-bodied and disabled. An external outlook is desirable; waiting areas may be shared between Units. The Waiting Area should be located in close proximity to public amenities.	
Amendment	14.03.05 First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		vinyl also acceptable
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH		or floor vinyl covered skirting
3000	Wall finish	Paint	Acrylic, washable			
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		as required, Equal to Acrovyn
7001	Windows					desirable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
23410	Bracket: television, wall mount	Metalwork	1	1	
2700	Chair: waiting	Furniture/ Fitting	3	18	some with arms; space required for a minimum of 2 wheelchairs
4900	Curtain track: window	Metalwork	1	1	optional
5410	Curtain: window, drapes	Furniture/ Fitting	3	1	optional; may also use blinds
17360	Pinboard: fabric covered	Furniture/ Fitting	2	2	or artwork, optional
16455	Rack: magazine	Furniture/ Fitting	3	1	
23295	Stand: public telephone	Furniture/ Fitting	3	1	optional
22800	Table: low	Furniture/ Fitting	3	2	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
41900	Telephone: public	3	1	yes	yes	—	—	—	—	—	—	optional
54580	Television: 54 cm	3	1	yes	—	—	—	—	—	—	—	

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Waiting - 25m2**

Room Tag: 4730
Room Code: WAIT-25

Services

ID	Description	Service Category	Qty	Remarks
1011	Telephone: public phone	Communications	1	optional
1090	TV: MATV	Communications	1	
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9015	GPO: Cleaner	Power	1	as required
9060	GPO: Special: for equipment	Power	2	TV, pay phone