

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 1170
Room Name	Anaesthetic Induction Room	Room Code: ANIN
Area	15.0 M2	
No of Rooms	1	
Subtotal of Area	15.0 M2	
Hours of Operation	Available 24 Hours	
Occupancy	1 patient; up to 3 staff	
Also covers these Rooms		
Description/ Special Requirements	<p>The Anaesthetic Room is for holding patients on mobile beds or trolleys prior to operative procedures at times when the Operating Room is not available. Local, regional or general anaesthesia may be administered in this area. Depending on special circumstances an Anaesthetic Induction Room of 18 m2 is also acceptable.</p> <p>Acoustics: Acoustic privacy is required</p> <p>Body Protected electrical area</p>	
Amendment	<p>10.10.03, - First Draft 03.03.05, - User review BOB; Hose support arm & suction added</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6015	Cornice	Plasterboard	Paint	Flush coved between wall & ceiling		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9125	Doors	Solid Core	Paint	1 1/2 leaf, observation panel		1500mm clear opening, sliding covers to obs panels
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin, tiles also acceptable
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	
1050	Bench: laminate	Furniture/ Fitting	1	1	open under part
15100	Bracket: monitor	Furniture/ Fitting	3	1	optional
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	on equipment rail
12300	Carrier: dirty linen, single	Furniture/ Fitting	3	1	
4430	Cupboard: drawer unit	Furniture/ Fitting	1	1	under bench

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Anaesthetic Induction Room**

Room Tag: 1170
Room Code: ANIN

ID	Description	Category	Group	Qty	Selection
4410	Cupboard: under bench	Furniture/ Fitting	1	1	
4380	Cupboard: wall mount, glass front	Furniture/ Fitting	1	1	over bench, lockable
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6163	Dispenser: mask	Furniture/ Fitting	3	1	to entry
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
1567	Hose support arm: wall mount	Furniture/ Fitting	3	1	optional
12900	Louvred panel: for storage-bins	Metalwork	1	3	457mmx457mm, over bench
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
7300	Rail: equipment	Metalwork	1	1	under services panel
19700	Sharps bin	Furniture/ Fitting	3	1	on bench
21755	Storage bins	Furniture/ Fitting	3	10	on louvred panels
21950	Suction adapter	Furniture/ Fitting	3	2	
22000	Suction bottle	Furniture/ Fitting	3	2	
23950	Trolley	Furniture/ Fitting	3	1	
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3100	Basin: scrub, Type A	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-A (sim)
9750	Clock: slave, analogue	1	1	yes	___	___	___	___	___	___	___	
32150	Light: procedure, ceiling	1	1	yes	___	___	___	___	___	___	___	small
36050	Monitor: cardiac	3	1	yes	opt	___	___	___	___	___	___	optional
43800	Refrigerator: under-bench, 120 Litre	3	1	yes	___	___	___	___	___	___	___	under bench, optional
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	to bench

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet on each panel for telephone
5005	Air conditioning: special	HVAC		positive pressure, filtered
6001	General: colour corrected	Lighting		variable lighting level
6055	Special: task light, built in	Lighting		under O/H cupboards
7020	Medical Air (MA)	Medical Gases	1	services panel
7010	Nitrous Oxide (N2O)	Medical Gases	1	services panel
7000	Oxygen (O2)	Medical Gases	2	services panel
7070	Scavenge	Medical Gases	1	services panel
7040	Suction	Medical Gases	2	services panel
8080	Emergency call	Nurse Call	1	+ indicator button & light
8090	Orderly/ Porter call	Nurse Call	1	optional
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9010	GPO: Emergency power, single	Power	2	patient services panel
9010	GPO: Emergency power, single	Power	4	to bench
9010	GPO: Emergency power, single	Power	1	monitor

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Anaesthetic Induction Room**

Room Tag: 1170
Room Code: ANIN

ID	Description	Service Category	Qty	Remarks
9000	GPO: Single	Power	4	patient services panel
9000	GPO: Single	Power	3	to walls (1 for fridge)
9060	Special: for equipment	Power	2	clock, procedure light
11000	Wall panel	Services Panels	1	recessed