

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 1230
Room Name	Anteroom	Room Code: ANRM
Area	6.0 M2	
No of Rooms	1	
Subtotal of Area	6.0 M2	
Minimum Dimension	0.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 - 2	
Also covers these Rooms		
Description/ Special Requirements	Anteroom or airlock associated with an Isolation room for maintenance of air pressurisation and for staff and visitors to change and dispose of protective gear used on entering or exit; a staff handwashing basin will be located within the room; glazing is recommended for patient visibility. Pressurisation - negative or positive depending on type of Isolation room	
	Body Protected electrical area	
Amendment	05.11.03, - First Draft 07.02.05, - BOB User review; fittings modified	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9115	Doors	Solid Core	Paint	1 1/2 leaf, half glazed		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin, tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
530	Basin vanity top	Furniture/ Fitting	1	1	
12300	Carrier: dirty linen, single	Furniture/ Fitting	3	1	in cupboard
3400	Coathook	Metalwork	1	4	2 inside cupboard, 2 on wall
4391	Cupboard: special	Furniture/ Fitting	1	1	with shelves & flip door for linen carrier
4350	Cupboard: tall	Furniture/ Fitting	1	1	with hooks for hanging gowns
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin

NSW Standard Project

Room Data Sheets

Department **Standard Components**
Room Name **Anteroom**

Room Tag: **1230**
Room Code: **ANRM**

ID	Description	Category	Group	Qty	Selection
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3120	Basin: vanity	1	1	___	___	yes	___	yes	yes	yes	___	Type B, elbow action levers

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		