

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 1830
Room Name	Dirty Utility, 12 m2	Room Code: DTUR-12
Area	12.0 M2	
No of Rooms	1	
Subtotal of Area	12.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 - 2 intermittently	
Also covers these Rooms		
Description/ Special Requirements	<p>The Dirty Utility provides for cleaning and holding of used equipment for collection and sterilisation elsewhere, disposal of clinical and other wastes and soiled linen, testing and disposing of patient specimens and decontamination and storage of patient utensils such as pans, urinals and bowls.</p> <p>Acoustics: Sound attenuation level - high; Acoustic privacy required</p>	
Amendment	<p>10.10.03, - First Draft 08.02.05, - BOB User review; fittings modified</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening, closer
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1010	Bench: stainless steel	Metalwork	1	1	with wet edge
1470	Bracket: sharps	Furniture/ Fitting	2	1	
12300	Carrier: dirty linen, single	Furniture/ Fitting	3	1	
3960	Container: covered	Furniture/ Fitting	3	1	under bench
4494	Cupboard: urinalysis	Furniture/ Fitting	1	1	over bench, optional
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
7200	Hook: equipment	Metalwork	1	2	for clean linen bags
9200	Hook: for catheter bag	Metalwork	1	2	above flushing rim sink

NSW Standard Project
Room Data Sheets

Department Standard Components
Room Name Dirty Utility, 12 m2

Room Tag: 1830
Room Code: DTUR-12

ID	Description	Category	Group	Qty	Selection
1455	Rack: bowl / basin	Metalwork	1	1	
16500	Rack: pan & urinal	Metalwork	1	2	total of 12 pans/12 urinals
19700	Sharps bin	Furniture/ Fitting	3	1	
19810	Shelf: SS, over bench	Metalwork	1	1	over bench
19820	Shelf: SS, under bench	Metalwork	1	1	@ 350mm AFFL
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin
24400	Whiteboard	Furniture/ Fitting	1	1	600x900, optional

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-B (sim)
49111	Sink: 450x350x250D	1	1	___	___	yes	opt	opt	yes	yes	___	hot water
49800	Sink: flushing rim	1	1	___	___	yes	___	___	___	yes	___	& pressure control spray hose
38700	Washer sanitiser: pan	1	1	yes	___	yes	yes	___	yes	yes	___	not hardwired
58200	Washer sanitiser: utensil	1	1	yes	___	yes	yes	___	yes	yes	___	

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics		
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	1	
9060	Special: for equipment	Power	2	Pan Washer, Utensil Washer