

NSW Standard Project
Room Data Sheets

| | | |
|--|--|---------------------------|
| Department | Standard Components | Room Tag: 1860 |
| Room Name | Disposal Room, 8m2 | Room Code: DISP- 8 |
| Area | 8.0 M2 | |
| No of Rooms | 1 | |
| Subtotal of Area | 8.0 M2 | |
| Hours of Operation | 24 Hours | |
| Occupancy | 1 - 2 intermittently | |
| Also covers these Rooms | | |
| Description/ Special Requirements | <p>The Disposal Room provides for the temporary holding of clinical waste, general waste, sharps, soiled linen and recyclables prior to removal. The Disposal Room should include a handwashing basin within the room if waste will be handled in this area.</p> <p>The room should be lockable.</p> | |
| Amendment | 10.10.03, - First Draft | |

Room Fabric and outline specifications

| ID | Fabric | Material | Finish | Specification | Selection | Remarks |
|------|-----------------|--------------|-------------------------|------------------------------|-----------|-------------------------------|
| 5030 | Ceiling | Plasterboard | Prefinished | Drop-in tiles, 600x1200 | | |
| 6030 | Cornice | Aluminium | Powdercoat | 24mm shadow angle | | |
| 8010 | Door protection | Composite | Prefinished PVC | Protection plate to 900 AFFL | | Equal to 'Acrovyn' |
| 8040 | Door protection | Composite | Prefinished PVC | To door frame | | Equal to 'Acrovyn' |
| 9001 | Doors | Solid Core | Paint | Single leaf | | 910mm clear opening, lockable |
| 1000 | Floor finish | Vinyl | Standard slip resistant | Seamless, coved | | |
| 2000 | Skirting | Vinyl | Prefinished | Floor vinyl coved, 150 mmH | | |
| 3000 | Wall finish | Paint | Acrylic, washable | | | |
| 3040 | Wall finish | Vinyl | Prefinished | Wall vinyl to 1200 AFFL | | |
| 3060 | Wall finish | Vinyl | Prefinished | Splashback | | to basin, if provided |
| 4030 | Wall protection | Composite | Prefinished PVC | Corner guards to 900 AFFL | | as required |

Fittings and Furniture (FF)

| ID | Description | Category | Group | Qty | Selection |
|-------|------------------------------|--------------------|-------|-----|----------------------------|
| 6154 | Dispenser: paper/ hand towel | Furniture/ Fitting | 2 | 1 | to hand basin, if provided |
| 6156 | Dispenser: soap | Furniture/ Fitting | 2 | 1 | to hand basin, if provided |
| 24125 | Waste bin: clinical | Furniture/ Fitting | 3 | 1 | 240 Litre |
| 24102 | Waste bin: general | Furniture/ Fitting | 3 | 2 | 240 Litre |
| 24100 | Waste bin: paper, 20 Litre | Furniture/ Fitting | 3 | 1 | to hand basin, if provided |

Fixtures, Equipment and associated Services (FE)

| ID | Description | Group | Qty | Ele | Data | CdW | HtW | WmW | Tap | Dns | Gas | Selection |
|------|-------------------------|-------|-----|-----|------|-----|-----|-----|-----|-----|-----|---------------------------------|
| 2850 | Basin: handwash, Type C | 1 | 1 | — | — | yes | — | yes | yes | yes | — | optional, refer to BHWS-C (sim) |

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Disposal Room, 8m2**

Room Tag: 1860
Room Code: DISP- 8

Services

| ID | Description | Service Category | Qty | Remarks |
|------|---------------------|------------------|-----|---------|
| 5000 | Airconditioning | HVAC | | |
| 5019 | Exhaust | HVAC | | |
| 6000 | General fluorescent | Lighting | | |