

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 2110
Room Name	Lounge - Patient, 15 m2	Room Code: LNPT-15
Area	15.0 M2	
No of Rooms	1	
Subtotal of Area	15.0 M2	
Minimum Dimension	0.0 M2	
Hours of Operation	24 Hours	
Occupancy	Up to 10 patients/ visitors; 1-2 staff intermittently	
Also covers these Rooms		
Description/ Special Requirements	<p>The Patient Lounge provides a change of environment away from clinical areas for patients and visitors. It is an area where family groups can visit and patients can socialise. An external outlook is essential.</p> <p>Acoustics: Sound attenuation level - Medium; Acoustic privacy required.</p> <p>Body Protected electrical area</p>	
Amendment	<p>10.10.03, - First Draft 08.02.05, - BOB User review, GPOs modified</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9115	Doors	Solid Core	Paint	1 1/2 leaf, half glazed		1400mm clear opening
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.		Vinyl also acceptable
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH		or floor vinyl coved skirting
3000	Wall finish	Paint	Acrylic, washable			
7001	Windows					essential

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
350	Artwork	Furniture/ Fitting	3	2	optional
1300	Bookcase	Furniture/ Fitting	3	1	optional
23410	Bracket: television, wall mount	Metalwork	1	1	optional
2655	Chair: visitor	Furniture/ Fitting	3	10	
4900	Curtain track: window	Metalwork	1	1	
5410	Curtain: window, drapes	Furniture/ Fitting	3	1	or blinds
22800	Table: low	Furniture/ Fitting	3	2	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
54510	Telephone: handset, standard	3	1	—	yes	—	—	—	—	—	—	on table, optional

NSW Standard Project
Room Data Sheets

Department Standard Components
Room Name Lounge - Patient, 15 m2

Room Tag: 2110
Room Code: LNPT-15

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
54580	Television: 54 cm	3	1	yes	—	—	—	—	—	—	—	on bracket, optional

Services

ID	Description	Service Category	Qty	Remarks
1090	TV: MATV	Communications	1	optional
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6046	Indirect lighting	Lighting		optional
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9000	GPO: Single	Power	6	
9060	Special: for equipment	Power	1	TV, optional