

**NSW Standard Project**  
**Room Data Sheets**

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 2410</b>
<b>Room Name</b>	<b>Office - Clinical/ Handover</b>	<b>Room Code: OFF-CLN</b>
<b>Area</b>	15.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	15.0 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	2 workstations; up to 10 for meetings	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	An Office adjoining the Staff Station for staff to write up notes, view digital imaging, hold confidential discussions, store records and have handovers.	
	Acoustics: Sound attenuation level - Medium; acoustic privacy required.	
<b>Amendment</b>	09.12.03, - First Draft	

**Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		
9002	Doors	Solid Core	Paint	Single leaf, half glazed		910mm clear opening, doors optional
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.		
7030	Observation	Alum/ glass	Powdercoat	Internal window, door height		Optional
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			

**Fittings and Furniture (FF)**

ID	Description	Category	Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	1	for workstations
2100	Chair: ergonomic, office	Furniture/ Fitting	3	2	
2400	Chair: stackable	Furniture/ Fitting	3	8	
17250	Pedestal drawer unit: mobile, 660mmH	Furniture/ Fitting	3	2	under bench
17360	Pinboard: fabric covered	Furniture/ Fitting	1	1	above bench
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over bench, full length
24400	Whiteboard	Furniture/ Fitting	2	1	1200x900

**Fixtures, Equipment and associated Services (FE)**

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
11400	Computer: PC & monitor	3	2	yes	yes	___	___	___	___	___	___	optional
41100	Printer: networked	3	1	yes	yes	___	___	___	___	___	___	optional
54510	Telephone: handset, standard	3	2	___	yes	___	___	___	___	___	___	

**NSW Standard Project**  
**Room Data Sheets**

**Department** | **Standard Components**  
**Room Name** | **Office - Clinical/ Handover**

**Room Tag: 2410**  
**Room Code: OFF-CLN**

**Services**

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet per workstation for telephone
1006	Voice / Data outlet: double	Communications	1	printer
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelving
8040	Annunciator	Nurse Call		to be audible in this room
9001	GPO: Double	Power	4	2 per workstation
9001	GPO: Double	Power	2	1-meeting area; 1-printer