

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 2640
Room Name	Patient Bay - Holding, 9m2	Room Code: PBTR-H-9
Area	9.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 patient; 1 - 2 staff intermittently	
Also covers these Rooms		
Description/ Special Requirements	<p>A Patient Bed Bay used for holding of patients prior to procedures, recovery of patients following procedures or for assessment and treatment of patients with non acute conditions. The Patient Bay will have close access to a staff handwashing basin.</p> <p>Body Protected electrical area</p>	
Amendment	<p>20.11.03, - First Draft 22.03.05, - BOB User review, Gr 3 fittings revised, louvred panel deleted</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3092	Wall protection	MDF	Laminate	Bed protection wall panel		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	to services panel
700	Bed: inpatient, manual	Furniture/ Fitting	3	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	optional
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	to services panel
21950	Suction adapter	Furniture/ Fitting	3	1	to services panel
22000	Suction bottle	Furniture/ Fitting	3	1	on bracket
23950	Trolley	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
31700	Light: examination, ceiling	1	1	yes	—	—	—	—	—	—	—	

NSW Standard Project

Room Data Sheets

Department **Standard Components**
Room Name **Patient Bay - Holding, 9m2**

Room Tag: **2640**
Room Code: **PBTR-H-9**

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6030	Special: downlights	Lighting		over bed
7020	Medical Air (MA)	Medical Gases	1	
7000	Oxygen (O2)	Medical Gases	1	
7040	Suction	Medical Gases	1	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	1 outlet for every 4 beds
9010	GPO: Emergency power, single	Power	3	
9000	GPO: Single	Power	3	
11000	Wall panel	Services Panels	1	flush mounted