

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 2690
Room Name	Plaster Room	Room Code: PLST
Area	14.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 patient; 2 -3 staff	
Also covers these Rooms		
Description/ Special Requirements	<p>The Plaster Room allows for the application of Plaster of Paris, or other splints, and for the closed reduction of displaced fractures or dislocations under sedative or regional anaesthesia.</p> <p>Sound attenuation level - high; acoustic privacy required</p> <p>Body protected electrical area</p>	
Amendment	<p>01.12.03, - First Draft</p> <p>01.03.05, - BOB User review, Gr 3 monitor added</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9125	Doors	Solid Core	Paint	1 1/2 leaf, observation panel		1400mm clear opening, sliding cover to glazing
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to 'Acrovyn'
3092	Wall protection	MDF	Laminate	Bed protection wall panel		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	
700	Bed: inpatient, manual	Furniture/ Fitting	3	1	
1010	Bench: stainless steel	Metalwork	1	1	with SS sink and wet edge
15100	Bracket: monitor	Furniture/ Fitting	3	1	wall mounted, optional
1470	Bracket: sharps	Furniture/ Fitting	2	1	on trolley
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	
4360	Cupboard: door ht adj. shelves	Furniture/ Fitting	1	1	lockable
4410	Cupboard: under bench	Furniture/ Fitting	1	1	adjustable shelf

NSW Standard Project

Room Data Sheets

Department **Standard Components**
 Room Name **Plaster Room**

Room Tag: **2690**
 Room Code: **PLST**

ID	Description	Category	Group	Qty	Selection
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, adjustable shelf
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	to basin
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
22000	Suction bottle	Furniture/ Fitting	3	1	
17501	Trolley: plaster	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-B (sim)
11400	Computer: PC & monitor	3	1	yes	yes	___	___	___	___	___	___	to bench, flat screen
31700	Light: examination, ceiling	1	1	yes	___	___	___	___	___	___	___	
36050	Monitor: cardiac	3	1	yes	opt	___	___	___	___	___	___	optional
40300	Plaster trap	1	1	___	___	___	___	___	___	yes	___	under sink
49110	Sink: 450x350x300D	1	1	___	___	yes	opt	opt	yes	yes	___	hot water
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	wall telephone
68700	Xray viewer: 2 screen	1	1	yes	___	___	___	___	___	___	___	

Services

ID	Description	Service Category	Qty	Remarks
1120	Monitor connection facilities and cabling	Communications	1	optional
1000	Telephone: PABX	Communications	1	wall telephone
1006	Voice / Data outlet: double	Communications	2	1 outlet on patient services panel for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
7020	Medical Air (MA)	Medical Gases	1	
7010	Nitrous Oxide (N2O)	Medical Gases	1	
7000	Oxygen (O2)	Medical Gases	1	
7070	Scavenge	Medical Gases	1	
7040	Suction	Medical Gases	1	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	3	to walls, bench
9010	GPO: Emergency power, single	Power	2	patient services panel
9010	GPO: Emergency power, single	Power	1	for monitor, optional
9000	GPO: Single	Power	4	patient services panel
9060	Special: for equipment	Power	2	XRV, exam light

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Plaster Room**

Room Tag: 2690
Room Code: PLST

ID	Description	Service Category	Qty	Remarks
11000	Wall panel	Services Panels	1	