

**NSW Standard Project**  
**Room Data Sheets**

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 2750</b>
<b>Room Name</b>	<b>Procedure Room - 14m2</b>	<b>Room Code: PROC-14</b>
<b>Area</b>	14.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	14.0 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 patient; 2 - 4 staff	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>The Procedure Room may be required for the performance of procedures that do not require the full facilities of the Operating Suite. This may include suturing or wounds, dressings, administration of local anaesthesia and use of medical gases in connection with the procedures being performed. General anaesthesia will not be administered in this room.</p> <p>Cardiac Protected electrical area</p> <p>Acoustics: Sound attenuation level - Medium. Acoustic privacy required.</p>	
<b>Amendment</b>	07.06.05, - First Draft	

**Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9125	Doors	Solid Core	Paint	1 1/2 leaf, observation panel		1400mm clear opening, cover to glazing
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening, optional door to Clean Utility
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		
3092	Wall protection	MDF	Laminate	Bed protection wall panel		

**Fittings and Furniture (FF)**

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	
700	Bed: inpatient, manual	Furniture/ Fitting	3	1	
1050	Bench: laminate	Furniture/ Fitting	1	1	
1470	Bracket: sharps	Furniture/ Fitting	2	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	
4420	Cupboard: under bench, lockable	Furniture/ Fitting	1	1	adjustable shelves

**NSW Standard Project**  
**Room Data Sheets**

**Department** | **Standard Components**  
**Room Name** | **Procedure Room - 14m2**

**Room Tag: 2750**  
**Room Code: PROC-14**

ID	Description	Category	Group	Qty	Selection
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, adjustable shelves
4600	Curtain track: bed screen	Metalwork	1	1	to door opening
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
19700	Sharps bin	Furniture/ Fitting	3	1	wall mounted
15150	Shelf: monitor	Furniture/ Fitting	1	1	or bracket, optional
21950	Suction adapter	Furniture/ Fitting	3	2	
22000	Suction bottle	Furniture/ Fitting	3	2	
23950	Trolley	Furniture/ Fitting	3	1	instrument / procedure
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

**Fixtures, Equipment and associated Services (FE)**

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3100	Basin: scrub, Type A	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-A (sim)
9700	Clock: analogue, electric	1	1	yes	___	___	___	___	___	___	___	
32150	Light: procedure, ceiling	1	1	yes	___	___	___	___	___	___	___	
36055	Monitor: cardiac with vital signs	3	1	yes	opt	___	___	___	___	___	___	optional
43800	Refrigerator: under-bench, 120 Litre	3	1	yes	___	___	___	___	___	___	___	optional
54520	Telephone: handset, handsfree	3	1	___	yes	___	___	___	___	___	___	
68700	Xray viewer: 2 screen	1	1	yes	___	___	___	___	___	___	___	recessed

**Services**

ID	Description	Service Category	Qty	Remarks
1120	Monitor connection facilities and cabling	Communications	1	
1006	Voice / Data outlet: double	Communications	2	1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	
7000	Oxygen (O2)	Medical Gases	2	
7040	Suction	Medical Gases	2	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button & light switch on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9030	Cardiac protected	Power		
9001	GPO: Double	Power	2	
9010	GPO: Emergency power, single	Power	4	services panel, 1 for monitor
9000	GPO: Single	Power	3	services panel
9060	Special: for equipment	Power	4	clock, XRV, light, fridge
11000	Wall panel	Services Panels	1	