

**NSW Standard Project**  
**Room Data Sheets**

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 2980</b>
<b>Room Name</b>	<b>Staff Station, 14m2</b>	<b>Room Code: SSTN-14</b>
<b>Area</b>	14.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	14.0 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	Up to 3 staff	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>The Staff Station is the administrative base for a Unit, and enquiry point for patients and visitors. It provides for the co-ordination of patient care, observation, writing up of clinical notes, entering data into computers and making and receiving telephone calls. The Staff Station may also accommodate a Unit Receptionist/ Clerk. The floor area may vary according to the Unit, activity level, number of full and part-time staff, the Operational Model and the building layout. The Staff Station 14m2 is suitable for a typical Inpatient Unit of 30 beds.</p> <p>Acoustics: Sound attenuation level - Medium; acoustic privacy required.</p> <p>Special Design Requirements:</p> <ul style="list-style-type: none"> <li>- Staff Station should have a set down area for disabled access</li> <li>- Lockable counter height doors may be provided for additional security if required.</li> </ul>	
<b>Amendment</b>	11.12.03, - First Draft	

**Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5007	Ceiling	Plasterboard	Paint	Bulkhead		optional
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
9050	Doors	Laminate	Prefinished	Single leaf, counter height		910mm clear opening, lockable, optional for security
9002	Doors	Solid Core	Paint	Single leaf, half glazed		910mm clear opening, optional to adjoining Office-Clinical/Write-up
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or featheredge skirting over carpet
3000	Wall finish	Paint	Acrylic, washable			
4010	Wall protection	Composite	Prefinished PVC	Combined rail & crash bar at 900 AFFL		to front of desk, optional

**Fittings and Furniture (FF)**

ID	Description	Category	Group	Qty	Selection
2100	Chair: ergonomic, office	Furniture/ Fitting	3	3	
4230	Counter top	Furniture/ Fitting	1	1	resinate or laminate, to staff station
11465	Keyboard shelf: drop down	Furniture/ Fitting	1	2	optional

# NSW Standard Project

## Room Data Sheets

Department **Standard Components**  
 Room Name **Staff Station, 14m2**

Room Tag: **2980**  
 Room Code: **SSTN-14**

ID	Description	Category	Group	Qty	Selection
17255	Pedestal filing unit: mobile, 660mmH	Furniture/ Fitting	3	2	under bench, lockable
17360	Pinboard: fabric covered	Furniture/ Fitting	1	1	to upstand of staff station
21250	Staff station: laminate/ timber	Furniture/ Fitting	1	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	under bench

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
11400	Computer: PC & monitor	3	2	yes	yes	—	—	—	—	—	—	
54510	Telephone: handset, standard	3	2	—	yes	—	—	—	—	—	—	
68700	Xray viewer: 2 screen	1	1	yes	—	—	—	—	—	—	—	recessed

### Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
5070	Temperature control	HVAC	1	control panel, optional
6000	General fluorescent	Lighting		
6030	Special: downlights	Lighting		dimnable for night lighting
6055	Special: task light, built in	Lighting		under countertop
7050	Gas Alarm Panel	Medical Gases	1	as required
8040	Annunciator	Nurse Call	1	
9001	GPO: Double	Power	4	
9060	Special: for equipment	Power	1	X-ray viewer
10005	Duress alarm	Security	1	