

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 1670
Room Name	Birthing Room - LDR	Room Code: BIRM
Area	28.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 patient; 1-2 support persons; up to 4 staff	
Also covers these Rooms		
Description/ Special Requirements	<p>The Birthing Room LDR provides for the entire process of delivery including patient preparation, relaxation and analgesia during labour, delivery, infant resuscitation, post natal recovery and observation. The Birthing Room shall include a scrub basin. Clinical items such as medical gases and services may be concealed but within easy reach.</p> <p>Acoustics: Sound attenuation level high: Acoustic privacy required</p> <p>Body Protected electrical area</p>	
Amendment	<p>24.01.05, - First Draft 03.03.05, - BOB User Review; boot rack & mirror deleted</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish		
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	2	optional
480	Bassinet	Furniture/ Fitting	3	1	
710	Bed: birthing, manual	Furniture/ Fitting	3	1	
1050	Bench: laminate	Furniture/ Fitting	1	1	
1470	Bracket: sharps	Furniture/ Fitting	2	1	mounted to trolley
23400	Bracket: television, ceiling	Metalwork	1	1	
2200	Chair: recliner	Furniture/ Fitting	3	1	

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Birthing Room - LDR**

Room Tag: 1670
Room Code: BIRM

ID	Description	Category	Group	Qty	Selection
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	
4391	Cupboard: special	Furniture/ Fitting	1	1	to conceal services
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench
4330	Cupboard: wardrobe	Furniture/ Fitting	1	1	
4600	Curtain track: bed screen	Metalwork	1	1	to door entry
4500	Curtain track: ceiling mounted	Metalwork	1	1	to baby resus area
4900	Curtain track: window	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	to door entry
5410	Curtain: window, drapes	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12450	Locker: bedside	Furniture/ Fitting	3	1	
12770	Lounge: 2 1/2 seat	Furniture/ Fitting	3	1	
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
16280	Oxygen/ nitrous mixer	Furniture/ Fitting	3	1	mobile
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
19800	Shelf: laminate	Furniture/ Fitting	1	1	near basin
21700	Stool: adjustable, mobile, high	Furniture/ Fitting	3	1	
21950	Suction adapter	Furniture/ Fitting	3	2	
22000	Suction bottle	Furniture/ Fitting	3	2	
16200	Table: overbed	Furniture/ Fitting	3	1	
23950	Trolley	Furniture/ Fitting	3	1	
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3100	Basin: scrub, Type A	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-A (sim)
26950	Infant resuscitaire	3	1	yes	___	___	___	___	___	___	___	
32700	Light: operating, single, mobile	3	1	yes	___	___	___	___	___	___	___	
35850	Monitor: foetal, CTG	3	1	yes	opt	___	___	___	___	___	___	mobile
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	
54550	Television: 34 cm	3	1	yes	___	___	___	___	___	___	___	

Services

ID	Description	Service Category	Qty	Remarks
1090	TV: MATV	Communications	1	
1006	Voice / Data outlet: double	Communications	2	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6110	Downlights: dimmable	Lighting		
6001	General: colour corrected	Lighting		
6050	Special: reading	Lighting		
7020	Medical Air (MA)	Medical Gases	2	1-mother; 1 baby

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Birth Room - LDR**

Room Tag: 1670
Room Code: BIRM

ID	Description	Service Category	Qty	Remarks
7010	Nitrous Oxide (N2O)	Medical Gases	1	1-mother
7000	Oxygen (O2)	Medical Gases	3	2-mother; 1-baby
7070	Scavenge	Medical Gases	1	mother - for N2O
7040	Suction	Medical Gases	2	1-mother; 1 baby
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button & light switch on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	3	bench & walls, optional
9010	GPO: Emergency power, single	Power	6	4-mother; 2- baby
9000	GPO: Single	Power	8	4-mother; 4-baby
9060	Special: for equipment	Power	1	TV