

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 2120
Room Name	Dark Room	Room Code: DARK
Area	6.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	Available 24 Hours	
Occupancy	1	
Also covers these Rooms		
Description/ Special Requirements	Dark room for processing and developing light sensitive radiographic film. Room requirements include good ventilation, light proof door and dark room lighting.	
Amendment	09.03.05, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
9001	Doors	Solid Core	Paint	Single leaf		light proof seals or revolving lightproof door
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1010	Bench: stainless steel	Metalwork	1	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to sink
6156	Dispenser: soap	Furniture/ Fitting	2	1	to sink
19820	Shelf: SS, under	Metalwork	1	1	under bench
20010	Shelving unit	Furniture/ Fitting	3	1	over bench
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
65000	IMG: processor, darkroom	3	1	yes	___	yes	___	___	___	yes	___	
65900	IMG: silver recovery unit	3	1	___	___	___	___	___	___	yes	___	
48910	Sink: 600x400x250D	1	1	___	___	yes	opt	opt	yes	yes	___	hot water

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Dark Room**

Room Tag: 2120
Room Code: DARK

ID	Description	Service Category	Qty	Remarks
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		
6052	Special: dark room safe light	Lighting		
9001	GPO: Double	Power	1	
9060	Special: for equipment	Power	1	darkroom processor