

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 2130
Room Name	Daylight Processing	Room Code: DPRO
Area	16.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 - 2	
Also covers these Rooms		
Description/ Special Requirements	Area for automatic daylight processing equipment with sorting and viewing of images and films. The processing area should be located with ready access to X-Ray procedure rooms and reporting rooms.	
Amendment	14.03.05, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to sink, tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	1	Sorting and viewing
1050	Bench: laminate	Furniture/ Fitting	1	1	with inset lab sink
1950	Chair: ergonomic, high	Furniture/ Fitting	3	1	to sorting bench
3350	Clock: battery operated	Furniture/ Fitting	1	1	
4410	Cupboard: under bench	Furniture/ Fitting	1	1	under sink bench
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over sink bench
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to sink
6156	Dispenser: soap	Furniture/ Fitting	2	1	to sink
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over sorting bench
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
65100	IMG: processor, daylight	3	1	yes	___	yes	___	___	yes	yes	___	
65900	IMG: silver recovery unit	3	1	___	___	___	___	___	___	yes	___	
49115	Sink: 600x450x450D	1	1	___	___	yes	opt	opt	yes	yes	___	hot water
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	on bench
69000	Xray viewer: 6 screen	1	1	yes	___	___	___	___	___	___	___	over bench

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Daylight Processing**

Room Tag: 2130
Room Code: DPRO

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	3	1 outlet on sorting bench for telephone
4037	Tundish drain	Hydraulics	1	for processor
9001	GPO: Double	Power	4	
9060	Special: for equipment	Power	1	for processor