

NSW Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 2260
Room Name	Dirty Utility - Sub	Room Code: DTUR-S
Area	8.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 - 2 intermittently	
Also covers these Rooms		
Description/ Special Requirements	<p>The Dirty Utility - Sub is a small Dirty Utility Room providing for cleaning and holding of used equipment for collection, disposal of clinical and other wastes and soiled linen testing and disposal of patient specimens. Decontamination and storage of patient bedpans, urinals and bowls is optional in the Dirty Utility-Sub.</p> <p>The Dirty Utility -Sub may be located in Allied Health, Imaging or Ambulatory Day Care areas. The room shall not be provided in Inpatient Units used for overnight stay.</p> <p>Acoustics: Sound attenuation level - high; Acoustic privacy is required</p>	
Amendment	24.01.05, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9004	Doors	Solid Core/ glass	Paint	Single leaf, observation panel		pull handle/push plate, closer
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1010	Bench: stainless steel	Metalwork	1	1	with wet edge
1470	Bracket: sharps	Furniture/ Fitting	2	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
9200	Hook: for catheter bag	Metalwork	1	2	above rim flushing sink
1455	Rack: bowl / basin	Metalwork	1	1	optional

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Dirty Utility - Sub**

Room Tag: 2260
Room Code: DTUR-S

ID	Description	Category	Group	Qty	Selection
16500	Rack: pan & urinal	Metalwork	1	1	6 pans/ 6 urinals, optional
19700	Sharps bin	Furniture/ Fitting	3	1	
19810	Shelf: SS, over	Metalwork	1	1	over bench
19820	Shelf: SS, under	Metalwork	1	1	
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-B (sim)
49111	Sink: 450x350x250D	1	1	___	___	yes	opt	opt	yes	yes	___	
49800	Sink: flushing rim	1	1	___	___	yes	___	___	___	yes	___	
38705	Washer sanitiser: pan & utensil combined	1	1	yes	___	yes	yes	___	yes	yes	___	optional

Services

ID	Description	Service Category	Qty	Remarks
5019	Exhaust	HVAC		
5015	Ventilation	HVAC		
4033	Floor waste	Hydraulics		
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	1	
9060	Special: for equipment	Power	1	Pan/ Utensil Washer-sanitiser