

NSW Standard Project
Room Data Sheets

| | | |
|--|---|-------------------------|
| Department | Standard Components | Room Tag: 2880 |
| Room Name | Mammography | Room Code: MAMMO |
| Area | 16.0 M2 | |
| No of Rooms | 1 | |
| Subtotal of Area | 16.0 M2 | |
| Hours of Operation | Available 24 Hours | |
| Occupancy | 1 patient; Up to 2 staff assisting | |
| Also covers these Rooms | | |
| Description/ Special Requirements | <p>X-ray room for mammography imaging procedures, with change area within the room.</p> <p>Acoustics: Acoustic privacy required</p> <p>Body Protected electrical area</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> - Radiation shielding as advised by Radiation Consultant - Cable ducts between X-ray table and control area may be required - 'X-ray in Use' lights required outside each entry door | |
| Amendment | 14.03.05, - First Draft | |

Room Fabric and outline specifications

| ID | Fabric | Material | Finish | Specification | Selection | Remarks |
|------|-----------------|------------|-------------------------|---------------------------------|-----------|----------------------|
| 5060 | Ceiling | Acoustic | Prefinished | Drop-in tiles, 600x1200 | | |
| 6030 | Cornice | Aluminium | Powdercoat | 24mm shadow angle | | |
| 8010 | Door protection | Composite | Prefinished PVC | Protection plate to 900 AFFL | | Equal to Acrovyn |
| 8040 | Door protection | Composite | Prefinished PVC | To door frame | | Equal to Acrovyn |
| 9130 | Doors | Solid Core | Paint | 1 1/2 leaf, with lead shielding | | 1400mm clear opening |
| 1000 | Floor finish | Vinyl | Standard slip resistant | Seamless, coved | | |
| 2000 | Skirting | Vinyl | Prefinished | Floor vinyl coved, 150 mmH | | |
| 3000 | Wall finish | Paint | Acrylic, washable | | | |
| 3060 | Wall finish | Vinyl | Prefinished | Splashback | | to basin |

Fittings and Furniture (FF)

| ID | Description | Category | Group | Qty | Selection |
|------|-------------------------------|--------------------|-------|-----|--------------------------|
| 1650 | Chair: client | Furniture/ Fitting | 3 | 1 | to change area |
| 2100 | Chair: ergonomic, office | Furniture/ Fitting | 3 | 1 | to desk |
| 2055 | Chair: mammography | Furniture/ Fitting | 3 | 1 | 'Hausted' |
| 3400 | Coathook | Metalwork | 1 | 2 | to change area, 1 @1200H |
| 4350 | Cupboard: tall | Furniture/ Fitting | 1 | 1 | adjustable shelves |
| 4700 | Curtain track: privacy screen | Metalwork | 1 | 1 | to change area |
| 5250 | Curtain: privacy screen | Furniture/ Fitting | 3 | 1 | to change area |
| 5900 | Desk | Furniture/ Fitting | 3 | 1 | |

NSW Standard Project
Room Data Sheets

Department | **Standard Components**
Room Name | **Mammography**

Room Tag: 2880
Room Code: MAMMO

| ID | Description | Category | Group | Qty | Selection |
|-------|------------------------------|--------------------|-------|-----|----------------------|
| 6152 | Dispenser: disposable glove | Furniture/ Fitting | 2 | 1 | |
| 6154 | Dispenser: paper/ hand towel | Furniture/ Fitting | 2 | 1 | to basin |
| 6156 | Dispenser: soap | Furniture/ Fitting | 2 | 1 | to basin |
| 6158 | Dispenser: soap antiseptic | Furniture/ Fitting | 2 | 1 | to basin |
| 13700 | Mirror | Metalwork | 1 | 1 | to change area |
| 20000 | Shelving unit: adjustable | Furniture/ Fitting | 1 | 1 | above desk, optional |
| 24100 | Waste bin: paper, 20 Litre | Furniture/ Fitting | 3 | 1 | to basin |

Fixtures, Equipment and associated Services (FE)

| ID | Description | Group | Qty | Ele | Data | CdW | HtW | WmW | Tap | Dns | Gas | Selection |
|-------|-------------------------------|-------|-----|-----|------|-----|-----|-----|-----|-----|-----|-----------------------|
| 2800 | Basin: handwash, Type B | 1 | 1 | ___ | ___ | yes | ___ | yes | yes | yes | ___ | refer to BHWS-B (sim) |
| 66700 | IMG: Mammography imaging unit | 1 | 1 | yes | yes | ___ | ___ | ___ | ___ | ___ | ___ | with control panel |
| 54510 | Telephone: handset, standard | 3 | 1 | ___ | yes | ___ | ___ | ___ | ___ | ___ | ___ | to desk |
| 68700 | Xray viewer: 2 screen | 1 | 1 | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | above desk |

Services

| ID | Description | Service Category | Qty | Remarks |
|-------|------------------------------|------------------|-----|---------------------------------|
| 1006 | Voice / Data outlet: double | Communications | 1 | to desk, 1 outlet for telephone |
| 5000 | Airconditioning | HVAC | | |
| 6110 | Downlights: dimmable | Lighting | | |
| 6001 | General: colour corrected | Lighting | | |
| 8080 | Emergency call | Nurse Call | 1 | |
| 8010 | Staff/ Nurse assist call | Nurse Call | 1 | |
| 9040 | Body protected | Power | | |
| 9001 | GPO: Double | Power | 3 | 2 to desk area |
| 9010 | GPO: Emergency power, single | Power | 2 | |
| 9060 | Special: for equipment | Power | 1 | Mammography unit |
| 12030 | Lead lining | Shielding | | to walls and doors as specified |