# Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

Department Standard Components Room Tag: 1040

Room Name 1 Bed Room - Isolation - Negative Pressure Room Code: 1 BR-IS-N-SJ

**Net Room Area Briefed** 

28.0 M2

No of Rooms

1

**Subtotal of Briefed Area** 

28.00 M2

**Hours of Operation** 

24 Hours

Occupancy

-+ 1 loui 5

Also covers these Rooms

1 patient; 1-2 staff; 1 - 2 visitors

Description/ Special Requirements Single bed room which may be used to isolate patients with known infectious conditions; natural light and outlook is essential. Glazing to room front and doors is recommended for patient visibility. The Isolation Room - Negative Pressure will require an internal staff handwash basin, direct access to ensuite toilet and shower facilities, and an Anteroom or Airlock to maintain air pressurisation.

Acoustics: Acoustic privacy is required.

Body Protected electrical area

**Amendment** 

13.03.2014 First issue

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400 clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
1045	Floor finish	Vinyl, non slip	Textured	Seamless, coved		under basin
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		to corridor side
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3067	Wall finish	Laminate	Prefinished			wall panels
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
4045	Wall protection	Timber	Clear finish	Corner guards		Where required
7001	Windows					Natural light & outlook essential.

### **Sharjah Healthcare City - Health Facility Guidelines** Milestone: Current

**Room Data Sheets** 

Department **Room Name** 

**Standard Components** 

Room Tag:

1040

1 Bed Room - Isolation - Negative Pressure

Room Code:

1 BR-IS-N-SJ

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	Medical air
1252 Blind: Venetian integral		Furniture/ Fitting	Furniture/ Fitting 1		to external, internal windows & door glazing, 2 way controls to internal windows
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	
23410	Bracket: television, wall mount	Metalwork	2	1	flat screen TV
2150	Chair: patient	Furniture/ Fitting	3	1	
2650	Chair: visitor, patient	Furniture/ Fitting	3	3	1 at desk
4391	Cupboard: special	Furniture/ Fitting	1	1	for refrigerator
4330	Cupboard: wardrobe	Furniture/ Fitting	1	1	
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
5910	Desk: built in	Furniture/ Fitting	1	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	near entry
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12450	Locker: bedside	Furniture/ Fitting	3	1	mobile, 2 lockable top drawers
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	
19800	Shelf: laminate	Furniture/ Fitting	1	1	for flowers
21950	Suction adapter	Furniture/ Fitting	3	1	
22000	Suction bottle	Furniture/ Fitting	3	1	
16200	Table: overbed	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin
24604	Window seat: built-in	Furniture/ Fitting	1	1	washable seat covering; with drawers under

# Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	<b>%</b> mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		elbow action levers
3700	Bed: inpatient, electric	3	1	yes								
54510	Telephone: handset, standard	3	1		yes							
3031	Television: flat screen	3	1	yes								wall mounted

## **Services**

ID	Description	Service Category	Qty	Selection / Remarks
1090	TV: MATV	Communications	1	
1006	Voice / Data outlet: double	Communications	2	1-patient services panel; 1-desk; 1 outlet for telephone to each panel
5000	Airconditioning	HVAC		
5050	Pressure: negative	HVAC		
6001	General: colour corrected	Lighting		
6065	Special: night lights	Lighting		
6050	Special: reading	Lighting		Up/down light
7020	Medical Air (MA)	Medical Gases	1	

### **Sharjah Healthcare City - Health Facility Guidelines** Milestone: Current

**Room Data Sheets** 

Page 3 of 3

**Standard Components** Department Room Tag: 1040 1 Bed Room - Isolation - Negative Pressure Room Code: **Room Name** 1 BR-IS-N-SJ

ID	Description	Service Category	Qty	Selection / Remarks
7000	Oxygen (O2)	Medical Gases	1	
7040	Suction	Medical Gases	1	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button & light switch on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	1	to desk
9010	GPO: Emergency power, single	Power	4	Bedhead
9000	GPO: Single	Power	1	Bedhead low level, for electric bed
9000	GPO: Single	Power	3	1 adjacent to patient chair; 1 to cupboard; 1 to wall near entry
9000	GPO: Single	Power	4	Bedhead
9060	GPO: Special: for equipment	Power	1	TV

Print Date: 20 May 2014 Provided by TAHPI for : Issue No: 1 Sharjah Domain Issue Date: 1 Apr 2014