Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Standard Components Room Tag: 1070

Room Name 1 Bed Room - Special, CCU Room Code: 1 BR-SP-SJ-B

Net Room Area Briefed

28.0 M2

No of Rooms

28.00 M2

Subtotal of Briefed Area

20.00 1112

Hours of Operation

24 Hours

Occupancy

Description/

1 patient; 1-2 visitors, 1-2 staff intermittently

Also covers these

Special Requirements

Rooms

A 1 Bed Room - Special, Coronary Care will accommodate one patient for the delivery of cardiac care treatment. Glazed doors and partition walls are

recommended for patient visibility and privacy. Natural light and outlook is essential; the room requires the ability to view out of the window from

either the chair or bed.

Acoustics: Acoustic privacy is required.

Body Protected Electrical Area

Amendment

13.03.2014 First issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint,	Flush set,		
			washable	suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening; latch set, observation panel optional
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Carpet also acceptable
1045	Floor finish	Vinyl, non slip	Textured	Seamless, coved		under basin
7055	Observation	Alum/ Glass	Powdercoat	Internal window, double glazed		with integral venetian blinds
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		Timber skirting if carpeted
3067	Wall finish	Laminate	Prefinished			wall panels
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
4045	Wall protection	Timber	Clear finish	Corner guards		Where required
7001	Windows					Natural light & outlook essential.

Issue Date: 1 Apr 2014

Sharjah Healthcare City - Health Facility Guidelines Mi

Milestone: Current

Room Data Sheets

Department Room Name

Standard Components
1 Bed Room - Special, CCU

Room Tag: Room Code:

1 BR-SP-SJ-B

1070

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	Medical air
1252	Blind: Venetian integral	Furniture/ Fitting	1	1	to internal window
1480	Bracket: ECG monitor	Furniture/ Fitting	3	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	
23410	Bracket: television, wall mount	Metalwork	1	1	flat screen TV
2050	Chair: lounge, sofa bed	Furniture/ Fitting	3	1	optional
2150	Chair: patient	Furniture/ Fitting	3	1	
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	
4391	Cupboard: special	Furniture/ Fitting	1	1	for refrigerator
4330	Cupboard: wardrobe	Furniture/ Fitting	1	1	
4600	Curtain track: bed screen	Metalwork	1	1	
4900	Curtain track: window	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
5410	Curtain: window, drapes	Furniture/ Fitting	3	1	set
5910	Desk: built in	Furniture/ Fitting	1	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	near basin
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12450	Locker: bedside	Furniture/ Fitting	3	1	mobile, 2 lockable drawers
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
19800	Shelf: laminate	Furniture/ Fitting	1	1	for flowers
21950	Suction adapter	Furniture/ Fitting	3	2	
22000	Suction bottle	Furniture/ Fitting	3	2	
16200	Table: overbed	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin
24604	Window seat: built-in	Furniture/ Fitting	1	1	with drawers under

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	%mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		refer to BHWS-B (sim)
3700	Bed: inpatient, electric	3	1	yes								
36050	Monitor: cardiac	3	1	yes	opt							may be telemetry
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
54510	Telephone: handset, standard	3	1		yes							
3031	Television: flat screen	3	1	yes								wall mounted

Services

ID	Description	Service Category	Qty	Selection / Remarks
1120	Monitor connection facilities and cabling	Communications	1	optional
1090	TV: MATV	Communications	1	
1006	Voice / Data outlet: double	Communications	2	1-patient services panel; 1-desk; 1 outlet for telephone to each panel

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Standard Components Room Tag: 1070

Room Name 1 Bed Room - Special, CCU Room Code: 1 BR-SP-SJ-B

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6060	Special: night lights	Lighting		
6050	Special: reading	Lighting		Up/down light
7020	Medical Air (MA)	Medical Gases	1	
7000	Oxygen (O2)	Medical Gases	2	
7040	Suction	Medical Gases	2	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button & light switch on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	1	desk
9010	GPO: Emergency power, single	Power	8	Bedhead
9000	GPO: Single	Power	3	1 adjacent to patient chair; 2 on walls
9000	GPO: Single	Power	1	Bedhead low level, for electric bed
9000	GPO: Single	Power	1	fridge (optional)
9060	GPO: Special: for equipment	Power	1	TV

Provided by TAHPI for : Sharjah Domain

Issue No:1 Print Date: 20 May 2014 Issue Date: 1 Apr 2014 Page 3 of 3