# Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

Department Room Name	Standard Components 2 Bed Room	Room Tag: Room Code:	1080 2 BR-ST-S					
Net Room Area Briefed	28.0 M2							
No of Rooms	1							
Subtotal of Briefed Area	28.00 M2							
Hours of Operation	24 Hours							
Occupancy	Up to 2 patients; 1-2 visitors each; 1-2 staff							
Also covers these Rooms								
Description/ Special Requirements	for the delivery of nursing and medical care. curtained and allow for treatment of patients the bed in a comfortable chair; natural light patients require the ability to view out of the bed. The room may also be used for obstetu natal, and may include bassinets. Each room is to have direct access to Ensu and the Unit corridor. The room layout is to around bedspaces.	have direct access to Ensuite toilet and shower facilities ridor. The room layout is to allow movement of equipment es. n may vary in configuration to suit different Ensuite options I Inboard Ensuite I Outboard Ensuite						
Amendment	Body Protected Electrical Area 13.03.2014 First issue							

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Carpet also acceptable
1045	Floor finish	Vinyl, non slip	Textured	Seamless, coved		under basin
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		with integral blinds, optional to outboard ensuite rooms

	Provided by TAHPI for :	Issue No: 1	Print Date:	20 May 2014
SHCC Guidelines	Sharjah Domain	Issue Date: 1 Apr 2014	Ļ	Page 1 of 3

## Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

#### **Room Data Sheets**

	DepartmentStandard ComponentsRoom Name2 Bed Room					Room Tag: Room Code:	1080 2 BR-ST-S	
ID	Fabric	Material	Finish	Specification	Selection	Remarks		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		timber skirti	ing if carpeted	
3067	Wall finish	Laminate	Prefinished			wall panels		
3000	Wall finish	Paint	Acrylic, washable					
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin		
3092	Wall protection	MDF	Laminate	Bed protection wall panel				
4045	Wall protection	Timber	Clear finish	Corner guards		Where requ	lired	
7001	Windows					Natural ligh essential.	t & outlook	

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	2	Medical air
480	Bassinet	Furniture/ Fitting	3	2	optional, if used for post-natal care
1252	Blind: Venetian integral	Furniture/ Fitting	1	1	optional; to internal window if provided
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	
23410	Bracket: television, wall mount	Metalwork	2	2	flat screen TVs
2150	Chair: patient	Furniture/ Fitting	3	2	
2650	Chair: visitor, patient	Furniture/ Fitting	3	2	
4330	Cupboard: wardrobe	Furniture/ Fitting	1	2	
4600	Curtain track: bed screen	Metalwork	1	2	
4900	Curtain track: window	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	2	
5410	Curtain: window, drapes	Furniture/ Fitting	3	1	set
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	near basin
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12450	Locker: bedside	Furniture/ Fitting	3	2	mobile, 2 lockable top drawers
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
19800	Shelf: laminate	Furniture/ Fitting	1	2	for flowers
21950	Suction adapter	Furniture/ Fitting	3	2	
22000	Suction bottle	Furniture/ Fitting	3	2	
16200	Table: overbed	Furniture/ Fitting	3	2	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	∕/mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		elbow action levers
3700	Bed: inpatient, electric	3	2	yes								
54510	Telephone: handset, standard	3	2		yes							
3031	Television: flat screen	3	2	yes								wall mounted

#### Services

	Provided by TAHPI for :	Issue No: 1	Print Date: 20 May 2014
SHCC Guidelines	Sharjah Domain	Issue Date: 1 Apr 201	4 Page 2 of 3

## Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

		Standard Components 2 Bed Room		Room Tag: Room Code:	1080 2 BR-ST-SJ
ID	Description	Service Category	Qty	Selection / Remarks	
1090	TV: MATV	Communications	2	1 / bed	
1006	Voice / Data outlet: double	Communications	2	1 / bed; one outlet for telepho	ne, each bed
5000	Airconditioning	HVAC			
6001	General: colour corrected	Lighting			
6060	Special: night lights	Lighting			
6050	Special: reading	Lighting	2	Up/down light	
7020	Medical Air (MA)	Medical Gases	2	1 / bed	
7000	Oxygen (O2)	Medical Gases	2	1 / bed	
7040	Suction	Medical Gases	2	1 / bed	
8080	Emergency call	Nurse Call	1	+ indicator button & light	
8005	Patient call handset	Nurse Call	2	call button & light switch on th	ne handset
8000	Patient/ Staff call	Nurse Call	2	+ indicator button & light	
8010	Staff/ Nurse assist call	Nurse Call	2	+ indicator button & light	
9040	Body protected	Power			
9015	GPO: Cleaner	Power	1		
9010	GPO: Emergency power, singl	e Power	8	4 / bed	
9000	GPO: Single	Power	8	4 / bed	
9000	GPO: Single	Power	4	1 adjacent to each patient cha	air; 2 on walls
9000	GPO: Single	Power	2	Bedhead low level, for electric	c bed/s
9060	GPO: Special: for equipment	Power	2	TVs	