Sharjah Healthcare City - Health Facility Guidelines

Room Data Sheets

Milestone: Current

Department Room Name	Standard Components 1 Bed Room - Special	Room Tag: Room Code:	1060 1 BR-SP-SJ-A			
Net Room Area Briefed	28.0 M2					
No of Rooms	1					
Subtotal of Briefed Area	28.00 M2					
Hours of Operation	24 Hours					
Occupancy	1 patient; 1-2 visitors, 1-2 staff intermittently					
Also covers these Rooms						
Description/ Special Requirements	nursing and medical care and treatment. It will accommodate special needs patients such as Care, Rehabilitation and High Dependency. T allows for larger or additional furniture and ec overnight stay by relatives. Natural light and o requires the ability to view out of the window	ed Room - Special will accommodate one patient for the delivery of ng and medical care and treatment. It will be a larger room to nmodate special needs patients such as Palliative Care, Sub-acute Rehabilitation and High Dependency. The additional floor area s for larger or additional furniture and equipment. It also permits hight stay by relatives. Natural light and outlook is essential; the room res the ability to view out of the window from either the chair or bed. booms for Palliative Care may also include a beverage making area a small refrigerator.				
	Acoustics: Acoustic privacy is required.					
A manual second	Body protected electrical area					
Amendment	13.03.2014 First issue					

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening; latch set, H/O device
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Carpet also acceptable
1045	Floor finish	Vinyl, non slip	Textured	Seamless, coved		under basin
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		timber skirting if carpeted
3067	Wall finish	Laminate	Prefinished			wall panels
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
4045	Wall protection	Timber	Clear finish	Corner guards		Where required

	Provided by TAHPI for :	Issue No: 1	Print Date: 20 May 2014
SHCC Guidelines	Sharjah Domain	Issue Date: 1 Apr 2014	4 Page 1 of 3

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

essential.

	•	artment m Name	Standard Co 1 Bed Room	-		Room Tag: Room Code:	1060 1 BR-SP-SJ-A
ID	Fabric	Material	Finish	Specification	Selection	Remarks	;
7001	Windows					Natural lig	ght & outlook

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	medical air
480	Bassinet	Furniture/ Fitting	3	1	optional
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	
23410	Bracket: television, wall mount	Metalwork	1	1	
2050	Chair: lounge, sofa bed	Furniture/ Fitting	3	1	optional
2150	Chair: patient	Furniture/ Fitting	3	2	1 to desk
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	
4391	Cupboard: special	Furniture/ Fitting	1	1	for refrigerator
4330	Cupboard: wardrobe	Furniture/ Fitting	1	1	
4600	Curtain track: bed screen	Metalwork	1	1	
4900	Curtain track: window	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
5410	Curtain: window, drapes	Furniture/ Fitting	3	1	set
5910	Desk: built in	Furniture/ Fitting	1	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	near basin
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12450	Locker: bedside	Furniture/ Fitting	3	1	mobile, 2 lockable drawers
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	
17360	Pinboard: fabric covered	Furniture/ Fitting	2	1	optional; above desk
19800	Shelf: laminate	Furniture/ Fitting	1	1	for flowers
21950	Suction adapter	Furniture/ Fitting	3	1	
22000	Suction bottle	Furniture/ Fitting	3	1	
16200	Table: overbed	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	V mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		refer to BHWS-B-U (sim)
3700	Bed: inpatient, electric	3	1	yes								
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
54510	Telephone: handset, standard	3	1		yes							
3031	Television: flat screen	3	1	yes								wall mounted

Services

ID	Description	Service Category	Qty	Selection / Remarks
1090	TV: MATV	Communications	1	
1006	Voice / Data outlet: double	Communications	2	1-patient services panel; 1-desk; 1 outlet for telephone to each panel
5000	Airconditioning	HVAC		

	Provided by TAHPI for :	Issue No: 1	Print Date:	20 May 2014
SHCC Guidelines	Sharjah Domain	Issue Date: 1 Apr 2014	4	Page 2 of 3

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

		Standard Components 1 Bed Room - Special		Room Tag: Room Code:	1060 1 BR-SP-SJ-A
ID	Description	Service Category	Qty	Selection / Remarks	
6001	General: colour corrected	Lighting			
6060	Special: night lights	Lighting			
6050	Special: reading	Lighting		up/down light	
7020	Medical Air (MA)	Medical Gases	1		
7000	Oxygen (O2)	Medical Gases	1		
7040	Suction	Medical Gases	1		
8080	Emergency call	Nurse Call	1	+ indicator button & light	
8005	Patient call handset	Nurse Call	1	call button & light switch on t	he handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light	
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light	
9040	Body protected	Power			
9015	GPO: Cleaner	Power	1		
9001	GPO: Double	Power	1	desk	
9010	GPO: Emergency power, single	e Power	4	Bedhead	
9000	GPO: Single	Power	4	Bedhead	
9000	GPO: Single	Power	1	adjacent to patient chair	
9000	GPO: Single	Power	1	Bedhead low level, for electr	ic bed
9000	GPO: Single	Power	1	Fridge (optional)	
9060	GPO: Special: for equipment	Power	1	TV	