# Sharjah Healthcare City - Health Facility Guidelines

**Room Data Sheets** 

Milestone: Current

Issue No: 1 Print Date: 20 May 2014

Issue Date: 1 Apr 2014

Page 1 of 3

| Department<br>Room Name              | Standard Components<br>1 Bed Room - Standard   | Room Tag:<br>Room Code:        | 1005<br>1 BR-ST-SJ |  |  |
|--------------------------------------|--|--------------------------------|--------------------|--|--|
| Net Room Area Briefed                | 18.0 M2  |                                |                    |  |  |
| No of Rooms                          | 1  |                                |                    |  |  |
| Subtotal of Briefed Area             | 18.00 M2   |                                |                    |  |  |
| Hours of Operation                   | 24 Hours   |                                |                    |  |  |
| Occupancy                            | 1 patient; 1-2 staff; 1-2 visitors   |                                |                    |  |  |
| Also covers these<br>Rooms           |  |                                |                    |  |  |
| Description/<br>Special Requirements | A 1 Bed Room will accommodate one patient for the delivery of nursing<br>and medical care and treatment; natural light and outlook is essential;<br>requires ability to view out of the window from either the chair or bed. The<br>1 Bed Room may also be used as an Isolation Room - Class S (Standard<br>Pressure). Door glazing and an internal window is recommended with<br>this option. |                                |                    |  |  |
|                                      | The 1 Bed Room may vary in configura<br>including:<br>- 1 BR-ST-A1 Inboard Ensuite<br>- 1 BR-ST-B1 Outboard Ensuite  | tion to suit different Ensuite | options            |  |  |
|                                      | Acoustics: Acoustic privacy required   |                                |                    |  |  |
|                                      | Body Protected Electrical Area   |                                |                    |  |  |
| Amendment                            | 13.03.2014 First issue   |                                |                    |  |  |

### Room Fabric and outline specifications

SHCC Guidelines

| ID   | Fabric          | Material             | Finish                  | Specification                    | Selection | Remarks   |
|------|-----------------|----------------------|-------------------------|----------------------------------|-----------|---|
| 5010 | Ceiling         | Plasterboard         | Paint,<br>washable      | Flush set, suspended             |           |   |
| 6025 | Cornice         | Aluminium            | Powdercoat              | shadow line                      |           |   |
| 8010 | Door protection | Composite            | Prefinished<br>PVC      | Protection plate to<br>900 AFFL  |           |   |
| 8040 | Door protection | Composite            | Prefinished<br>PVC      | To door frame                    |           |   |
| 9125 | Doors           | Solid Core/<br>Glass | Paint                   | 1 1/2 leaf,<br>observation panel |           | 1200mm (single door)/<br>1400mm (1+1/2 door) clear<br>opening, half leaf optional;<br>obs panel for Isolation use |
| 1000 | Floor finish    | Vinyl                | Standard slip resistant | Seamless, coved                  |           | carpet also acceptable  |
| 1045 | Floor finish    | Vinyl, non slip      | Textured                | Seamless, coved                  |           | under basin   |
| 7030 | Observation     | Alum/ Glass          | Powdercoat              | Internal window,<br>door height  |           | optional, to rooms with an outboard ensuite   |
| 7010 | Observation     | Glass                | Clear                   | Through door/s                   |           | for Isolation Room use  |
| 2000 | Skirting        | Vinyl                | Prefinished             | Floor vinyl coved,<br>150 mmH    |           | timber skirting if carpeted   |
| 3067 | Wall finish     | Laminate             | Prefinished             |                                  |           | wall panels   |
| 3000 | Wall finish     | Paint                | Acrylic,<br>washable    |                                  |           |   |

Provided by TAHPI for :

Sharjah Domain

# Sharjah Healthcare City - Health Facility Guidelines

#### **Room Data Sheets**

Milestone: Current

|      | Department Standard Components<br>Room Name 1 Bed Room - Standard |                  |              |                           | F         | Room Tag:<br>Room Code:    | 1005<br>1 BR-ST-SJ |
|------|---|------------------|--------------|---------------------------|-----------|----------------------------|--------------------|
| ID   | Fabric  | Material         | Finish       | Specification             | Selection | Remarks                    |                    |
| 3022 | Wall finish   | Resinate,<br>6mm | Prefinished  | Splashback                |           | to basin                   |                    |
| 3092 | Wall protection   | MDF              | Laminate     | Bed protection wall panel |           |                            |                    |
| 4045 | Wall protection   | Timber           | Clear finish | Corner guards             |           | where requ                 | uired              |
| 7001 | Windows   |                  |              |                           |           | natural ligh<br>essential. | nt & outlook       |

## Fittings and Furniture (FF)

| ID    | Description                     | Category           | Group | Qty | Selection / Remarks                                    |
|-------|---------------------------------|--------------------|-------|-----|--|
| 150   | Air flowmeter                   | Furniture/ Fitting | 3     | 1   | Medical air  |
| 1252  | Blind: Venetian integral        | Furniture/ Fitting | 1     | 1   | if internal observation window provided, 2 way control |
| 1465  | Bracket: suction bottle         | Furniture/ Fitting | 2     | 1   |  |
| 23410 | Bracket: television, wall mount | Metalwork          | 2     | 1   | flat screen TV   |
| 2150  | Chair: patient                  | Furniture/ Fitting | 3     | 1   |  |
| 2650  | Chair: visitor, patient         | Furniture/ Fitting | 3     | 1   |  |
| 4391  | Cupboard: special               | Furniture/ Fitting | 1     | 1   | for refrigerator                                       |
| 4330  | Cupboard: wardrobe              | Furniture/ Fitting | 1     | 1   |  |
| 4600  | Curtain track: bed screen       | Metalwork          | 1     | 1   |  |
| 4900  | Curtain track: window           | Metalwork          | 1     | 1   |  |
| 5000  | Curtain: bed screen             | Furniture/ Fitting | 3     | 1   |  |
| 5410  | Curtain: window, drapes         | Furniture/ Fitting | 3     | 1   | set  |
| 5910  | Desk: built in                  | Furniture/ Fitting | 1     | 1   |  |
| 6152  | Dispenser: disposable glove     | Furniture/ Fitting | 2     | 1   |  |
| 6154  | Dispenser: paper/ hand towel    | Furniture/ Fitting | 2     | 1   | to basin   |
| 6156  | Dispenser: soap                 | Furniture/ Fitting | 2     | 1   | to basin   |
| 6158  | Dispenser: soap antiseptic      | Furniture/ Fitting | 2     | 1   | to basin   |
| 12450 | Locker: bedside                 | Furniture/ Fitting | 3     | 1   | mobile, 2 lockable top drawers                         |
| 16250 | Oxygen flowmeter                | Furniture/ Fitting | 3     | 1   |  |
| 19800 | Shelf: laminate                 | Furniture/ Fitting | 1     | 1   | for flowers  |
| 21950 | Suction adapter                 | Furniture/ Fitting | 3     | 1   |  |
| 22000 | Suction bottle                  | Furniture/ Fitting | 3     | 1   |  |
| 16200 | Table: overbed                  | Furniture/ Fitting | 3     | 1   |  |
| 24100 | Waste bin: paper, 20 Litre      | Furniture/ Fitting | 3     | 1   | to basin   |
| 24604 | Window seat: built-in           | Furniture/ Fitting | 1     | 1   | optional   |

## Fixtures, Equipment and associated Services (FE)

| ID    | Description                          | Group | Qty | Ele | Data | CdW | HtW | ₩m₩ | Тар | Dns | Gas | Selection / Remarks   |
|-------|--------------------------------------|-------|-----|-----|------|-----|-----|-----|-----|-----|-----|-----------------------|
| 2800  | Basin: handwash, Type B              | 1     | 1   |     |      | yes |     | yes | yes | yes |     | refer to BHWS-B (sim) |
| 3700  | Bed: inpatient, electric             | 3     | 1   | yes |      |     |     |     |     |     |     |                       |
| 43800 | Refrigerator: under-bench, 120 Litre | 3     | 1   | yes |      |     |     |     |     |     |     | optional              |
| 54510 | Telephone: handset, standard         | 3     | 1   |     | yes  |     |     |     |     |     |     |                       |
| 3031  | Television: flat screen              | 3     | 1   | yes |      |     |     |     |     |     |     | wall mounted          |

#### Services

| ID | Description    |                 | Service Category | Qty | Selection   | / Remarks   |             |
|----|----------------|-----------------|------------------|-----|-------------|-------------|-------------|
|    |                | Provided by TAF | IPI for :        |     | Issue No: 1 | Print Date: | 20 May 2014 |
| 5  | HCC Guidelines | Sharjah Domain  |                  | ls  | sue Date: 1 | Apr 2014    | Page 2 of 3 |

# Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current Room Data Sheets

|      | Department Star<br>Room Name 1 Be | Room Tag: 1005<br>Room Code: 1 BR-ST-SJ |     |  |
|------|-----------------------------------|---|-----|--|
| ID   | Description                       | Service Category                        | Qty | Selection / Remarks  |
| 1090 | TV: MATV                          | Communications                          | 1   |  |
| 1006 | Voice / Data outlet: double       | Communications                          | 2   | 1-patient services panel; 1-desk; 1 outlet for telephone to each panel |
| 5000 | Airconditioning                   | HVAC                                    |     |  |
| 6001 | General: colour corrected         | Lighting                                |     |  |
| 6060 | Special: night lights             | Lighting                                |     |  |
| 6050 | Special: reading                  | Lighting                                |     | Up/down light  |
| 7020 | Medical Air (MA)                  | Medical Gases                           | 1   |  |
| 7000 | Oxygen (O2)                       | Medical Gases                           | 1   |  |
| 7040 | Suction                           | Medical Gases                           | 1   |  |
| 8080 | Emergency call                    | Nurse Call                              | 1   | + indicator button & light   |
| 8005 | Patient call handset              | Nurse Call                              | 1   | call button & light switch on the handset                              |
| 8000 | Patient/ Staff call               | Nurse Call                              | 1   | + indicator button & light   |
| 8010 | Staff/ Nurse assist call          | Nurse Call                              | 1   | + indicator button & light   |
| 9040 | Body protected                    | Power                                   |     |  |
| 9015 | GPO: Cleaner                      | Power                                   | 1   |  |
| 9001 | GPO: Double                       | Power                                   | 1   | to desk  |
| 9010 | GPO: Emergency power, single      | Power                                   | 4   | Bedhead  |
| 9000 | GPO: Single                       | Power                                   | 4   | Bedhead  |
| 9000 | GPO: Single                       | Power                                   | 3   | adjacent to patient chair; 2 on walls                                  |
| 9000 | GPO: Single                       | Power                                   | 2   | 1-Bedhead low level, for electric bed;<br>1-refrigerator in cupboard   |
| 9060 | GPO: Special: for equipment       | Power                                   | 1   | TV   |