Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Print Date: 20 May 2014

Page 1 of 1

Issue No: 1

Issue Date: 1 Apr 2014

Department	Standard Components	Room Tag:	1200
Room Name	Airlock, 6m2	Room Code:	AIRL-6-SJ

Net Room Area Briefed

6.0 M2

No of Rooms

'

Subtotal of Briefed Area

6.00 M2

Hours of Operation

24 Hours

Occupancy

N/A

Also covers these

Rooms

Description/ Special Requirements Airlock entry to a Unit to maintain air pressurisation. Entry doors may be automatic. Access to the Unit may require intercom or special security provisions.

Amendment

13.03.2014 First issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening,observation panel optional; may be automatic, lockable; entry doors may require security features
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900AFFL		

Services

ID	Description	Service Category	Qty	Selection / Remarks
1035	Door buzzer	Communications	1	optional; to entry door
1040	Intercom	Communications	1	optional; to entry door
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9015	GPO: Cleaner	Power	1	