#### **Sharjah Healthcare City - Health Facility Guidelines** Milestone: Current

**Room Data Sheets** 

**Standard Components** 1712 Department Room Tag: **Calibration / Testing Shop Room Name** Room Code: CAL-TEST-30-SJ

**Net Room Area Briefed** 

30.0 M2

No of Rooms

**Subtotal of Briefed Area** 

30.00 M2

**Hours of Operation** 

Available 24 Hours

Occupancy

Up to 4 staff

Also covers these

Rooms

Remarks

4 work benches

Description/ **Special Requirements** 

A secure workroom provided for the calibration and testing of biomedical equipment used in the complex. Space will be required for parking of mobile items of equipment. This workshop will include all medical gases and all laboratory gases for testing and calibrating equipment. This workshop should be located with direct access to the Biomedical Workshop.

**Amendment** 

13.03.2014 First issue

### **Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH		
3026	Wall finish	PVC	Prefinished panel	Splashback		to basin
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		
7001	Windows					desirable

# Fittings and Furniture (FF)

Description	Category	Group	Qty	Selection / Remarks
Bench: laminate	Furniture/ Fitting	1	1	to 2 sides of room; workstation for 4 persons
Blind: Venetian	Metalwork	3	1	if external window provided
Chair: ergonomic, high	Furniture/ Fitting	3	4	
Cupboard: double door lockable	Furniture/ Fitting	3	1	storage
Cupboard: drawer unit	Furniture/ Fitting	1	4	under bench, 1 to each workstation
	Bench: laminate  Blind: Venetian  Chair: ergonomic, high  Cupboard: double door lockable	Bench: laminate  Furniture/ Fitting  Blind: Venetian  Chair: ergonomic, high  Cupboard: double door lockable  Furniture/ Fitting	Bench: laminate Furniture/ Fitting 1  Blind: Venetian Metalwork 3  Chair: ergonomic, high Furniture/ Fitting 3  Cupboard: double door lockable Furniture/ Fitting 3	Bench: laminate Furniture/ Fitting 1 1  Blind: Venetian Metalwork 3 1  Chair: ergonomic, high Furniture/ Fitting 3 4  Cupboard: double door lockable Furniture/ Fitting 3 1

Issue Date: 1 Apr 2014

# **Sharjah Healthcare City - Health Facility Guidelines**

Milestone: Current

**Room Data Sheets** 

Print Date: 20 May 2014

Page 2 of 2

Issue No: 1

Issue Date: 1 Apr 2014

Department Standard Components Room Tag: 1712
Room Name Calibration / Testing Shop Room Code: CAL-TEST-30-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
20000	Shelving unit: adjustable	Furniture/ Fitting	1	2	over workstations
19970	Shelving unit: heavy duty	Furniture/ Fitting	1	1	full height shelving unit; adjustable shelves for smaller equipment items
24125	Waste bin: clinical	Furniture/ Fitting	3	1	to basin; optional
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

# Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	<b>V</b> mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		wrist or sensor operated
												taps
11400	Computer: PC & monitor	3	2	yes	yes							
54510	Telephone: handset, standard	3	2		yes							

### **Services**

ID	Description	Service Category	Qty	Selection / Remarks		
1006	Voice / Data outlet: double	Communications	9	2/workstation; 1-wall		
5000	Airconditioning	HVAC				
6000	General fluorescent	Lighting				
6055	Special: task light, built in	Lighting		under O/H shelving		
7024	Carbon Dioxide (CO2)	Medical Gases	1	for testing/ calibrating equipment		
7020	Medical Air (MA)	Medical Gases	2	for testing/ calibrating equipment; MA-4 & MA-7		
7015	Nitrogen	Medical Gases	1	for testing/ calibrating equipment; other laboratory gases as specified		
7010	Nitrous Oxide (N2O)	Medical Gases	1	for testing/ calibrating equipment		
7000	Oxygen (O2)	Medical Gases	1	for testing/ calibrating equipment		
7070	Scavenge	Medical Gases	1			
7040	Suction	Medical Gases	1	for testing/ calibrating equipment		
9001	GPO: Double	Power	17	4/workstation; 1-wall		
9011	GPO: Emergency power, double	Power	4	1/workstation		
11000	Wall panel	Services Panels	1	services duct for gases, power & data		