Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Standard Components Room Tag: 1860
Room Name Clean-Up Room, 7m2 Room Code: CLUP-7-SJ

Net Room Area Briefed

7.0 M2

No of Rooms

1

Subtotal of Briefed Area

7.00 M2

Hours of Operation

24 Hours

Occupancy

1 - 2

Also covers these Rooms

Description/
Special Requirements

The Clean-Up Room is used for holding of used trolleys and articles from an Operating or Procedure room. Items may be sorted, rinsed or disposed of and despatched to waste holding/ CSSU areas as appropriate.

Amendment

13.03.2014 First issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		As required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1010	Bench: stainless steel	Metalwork	1	1	with wet edge
1470	Bracket: sharps	Furniture/ Fitting	2	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2 1		
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
15400	Hook rack: mops	Metalwork	1	1	4 hooks
12300	Linen carrier: dirty, single	Furniture/ Fitting	3	1	
19700	Sharps bin	Furniture/ Fitting	3	1	
19820	Shelf: SS, under	Metalwork	1	1	under SS bench
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over bench
23950	Trolley	Furniture/ Fitting	3	1	
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current

Room Data Sheets

Print Date: 20 May 2014

Page 2 of 2

Issue No: 1

Issue Date: 1 Apr 2014

Department Room Name

Standard Components Clean-Up Room, 7m2 Room Tag: Room Code: 1860 CLUP-7-SJ

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	//mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		elbow action levers
49111	Sink: 450x350x250D	1	1			yes	opt	opt	yes	yes		hot water
49200	Sink: cleaner	1	1			yes	yes		yes	yes		

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		