Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Standard Components 1930 Department Room Tag: Clean Utility - Sub, 8m2 **Room Name Room Code:** CLUR-8-SJ

Net Room Area Briefed

8.0 M2

No of Rooms

Subtotal of Briefed Area

8.00 M2

Hours of Operation

24 Hours

Occupancy

1 - 2 intermittently

Also covers these

Rooms

Description/

Special Requirements

A small Clean Utility for the storage and preparation of clean and sterile stock, patient care items and secure storage of medications. The Clean Utility-Sub should not be provided in Inpatient Units used for overnight stay.

Secured staff only access to the room may be required.

Amendment

13.03.2014 First issue

Room Fabric and outline specifications

| ID | Fabric | Material | Finish | Specification | Selection | Remarks |
|------|-----------------|----------------------|-------------------------|-----------------------------------|-----------|-------------------------------|
| 5010 | Ceiling | Plasterboard | Paint, washable | Flush set, suspended | | for security reasons |
| 6025 | Cornice | Aluminium | Powdercoat | shadow line | | |
| 8010 | Door protection | Composite | Prefinished PVC | Protection plate to 900 AFFL | | |
| 8040 | Door protection | Composite | Prefinished PVC | To door frame | | |
| 9004 | Doors | Solid Core/ Glass | Paint | Single leaf, observation panel | | 920mm clear opening, lockable |
| 1000 | Floor finish | Vinyl | Standard slip resistant | Seamless, coved | | |
| 2000 | Skirting | Vinyl | Prefinished | Floor vinyl coved, 150 mmH | | |
| 3000 | Wall finish | Paint | Acrylic, washable | | | |
| 3052 | Wall finish | Vinyl | Prefinished | Wall vinyl to 1500AFFL | | |

Fittings and Furniture (FF)

| ID | Description | Category | Group | Qty | Selection / Remarks |
|------|----------------------------------|--------------------|-------|-----|-----------------------------------|
| 1050 | Bench: laminate | Furniture/ Fitting | 1 | 1 | |
| 1470 | Bracket: sharps | Furniture/ Fitting | 2 | 1 | mounted to side of bench |
| 4375 | Cupboard: medication, lockable | Furniture/ Fitting | 1 | 1 | with drug safe |
| 4410 | Cupboard: under bench | Furniture/ Fitting | 1 | 1 | with adjustable shelf |
| 4470 | Cupboard: wall mounted, lockable | Furniture/ Fitting | 1 | 1 | over bench, with adjustable shelf |
| 6157 | Dispenser: medicated hand gel | Furniture/ Fitting | 2 | 1 | optional |
| 6154 | Dispenser: paper/ hand towel | Furniture/ Fitting | 2 | 1 | to hand basin |
| 6156 | Dispenser: soap | Furniture/ Fitting | 2 | 1 | to hand basin |
| 6158 | Dispenser: soap antiseptic | Furniture/ Fitting | 2 | 1 | to hand basin |

Sharjah Healthcare City - Health Facility Guidelines

Room Data Sheets

Milestone: Current

DepartmentStandard ComponentsRoom Tag:1930Room NameClean Utility - Sub, 8m2Room Code:CLUR-8-SJ

| ID | Description | Category | Group | Qty | Selection / Remarks |
|-------|---------------------------------|--------------------|-------|-----|------------------------|
| 12900 | Louvred panel: for storage-bins | Metalwork | 1 | 2 | above bench, optional |
| 17312 | Pharmacy bin; returns | Furniture/ Fitting | 3 | 1 | |
| 19060 | Safe: dangerous drugs, small | Furniture/ Fitting | 1 | 1 | in medication cupboard |
| 19700 | Sharps bin | Furniture/ Fitting | 3 | 1 | |
| 24100 | Waste bin: paper, 20 Litre | Furniture/ Fitting | 3 | 1 | to hand basin |

Fixtures, Equipment and associated Services (FE)

| ID | Description | Group | Qty | Ele | Data | CdW | HtW | / mW | Тар | Dns | Gas | Selection / Remarks |
|-------|--------------------------------------|-------|-----|-----|------|-----|-----|-------------|-----|-----|-----|---------------------|
| 2800 | Basin: handwash, Type B | 1 | 1 | | | yes | | yes | yes | yes | | elbow action levers |
| 43800 | Refrigerator: under-bench, 120 Litre | 3 | 1 | yes | | | | | | | | optional |
| 54510 | Telephone: handset, standard | 3 | 1 | | yes | | | | | | | optional, on bench |

Services

| ID | Description | Service Category | Qty | Selection / Remarks |
|------|-------------------------------|------------------|-----|---------------------------|
| 1006 | Voice / Data outlet: double | Communications | 1 | |
| 5000 | Airconditioning | HVAC | | |
| 6000 | General fluorescent | Lighting | | |
| 6055 | Special: task light, built in | Lighting | 1 | under O/H cupboards |
| 9000 | GPO: Single | Power | 1 | Refrigerator, under bench |
| 9000 | GPO: Single | Power | 4 | |

SHCC Guidelines

Provided by TAHPI for:

Sharjah Domain

Issue No: 1

Print Date: 20 May 2014

Sharjah Domain

Issue Date: 1 Apr 2014

Page 2 of 2