#### **Sharjah Healthcare City - Health Facility Guidelines** Milestone: Current

**Room Data Sheets** 

**Standard Components** 2310 Department Room Tag: **Echocardiography Room Code: Room Name ECHO-SJ** 

**Net Room Area Briefed** 

30.0 M2

No of Rooms

**Subtotal of Briefed Area** 

30.00 M2

**Hours of Operation** 

Available 24 Hours

Occupancy

1 patient; 1 - 2 staff

Also covers these

Rooms

Description/ **Special Requirements** 

Room for diagnostic echocardiography procedures including trans-oesophageal echocardiography. Echocardiography procedures may be performed under local anaesthesia. The Echocardiography room should be located close to patient toilet and change rooms.

Acoustics: Acoustic privacy required

Body Protected electrical area

**Amendment** 

13.03.2014 First issue

### **Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening; single leaf to achieve 920mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin; tiles also acceptable

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	patient services panel
1050	Bench: laminate	Furniture/ Fitting	1	1	
1650	Chair: client	Furniture/ Fitting	3	1	
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
3350	Clock: battery operated	Furniture/ Fitting	3	1	
3400	Coathook	Metalwork	1	1	

Issue Date: 1 Apr 2014

# **Sharjah Healthcare City - Health Facility Guidelines**

Milestone: Current

Room Data Sheets

DepartmentStandard ComponentsRoom Tag:2310Room NameEchocardiographyRoom Code:ECHO-SJ

ID	Description	Category	Group	Qty	Selection / Remarks		
4360	Cupboard: door ht adj. shelves	Furniture/ Fitting	1	1			
4410	Cupboard: under bench	Furniture/ Fitting	1	1	adjustable shelves		
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench		
4700	Curtain track: privacy screen	Metalwork	1	1	to entry door		
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to entry door		
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1			
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin		
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin		
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin		
7500	Examination couch	Furniture/ Fitting	3	1			
8100	Footstool	Furniture/ Fitting	3	1			
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	patient services panel		
21950	Suction adapter	Furniture/ Fitting	3	1	patient services panel		
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin		

## Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	<b>V</b> mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		
19200	IMG: Echocardiography machine	3	1	yes								
31700	Light: examination, ceiling	1	1	yes								optional
54510	Telephone: handset, standard	3	1		yes							to bench
68700	Xray viewer: 2 screen	1	1	yes								optional

### **Services**

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	2	
5000	Airconditioning	HVAC		
6110	Downlights: dimmable	Lighting		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
8080	Emergency call	Nurse Call	1	
8005	Patient call handset	Nurse Call	2	1- bed area; 1 - exam couch; bed and couch may share one point if handset will reach both
8000	Patient/ Staff call	Nurse Call	2	1- bed area; 1 - exam couch; bed and couch may share one point if handset will reach both
8010	Staff/ Nurse assist call	Nurse Call	1	
9040	Body protected	Power		
9001	GPO: Double	Power	4	
9010	GPO: Emergency power, single	Power	4	patient services panel
9000	GPO: Single	Power	2	to exam couch
9060	GPO: Special: for equipment	Power	3	Echocardigraphy machine, exam light, XRV

Provided by TAHPI for : Sharjah Domain

Issue No:1 Print Date: 20 May 2014 Issue Date: 1 Apr 2014 Page 2 of 2