

Department	Standard Components	Room Tag:	2320
Room Name	Ensuite - Bariatric	Room Code:	ENS-BA-SJ
Net Room Area Briefed	7.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	7.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1-2 staff assisting		
Also covers these Rooms			
Description/ Special Requirements	<p>An Ensuite - Bariatric is designed to meet the needs of bariatric (obese or morbidly obese) patients allowing the patient to wash, shave, groom themselves, shower and use the toilet, either independently or with assistance.</p> <p>The Ensuite - Bariatric is associated with the 1 Bed Room - Bariatric: the additional area and layout will facilitate two assisting nurses and a shower commode with bariatric capacity. A ceiling patient lifter is optional; mobile patient lifters will not routinely be used within this space but the ensuite should accommodate this equipment in the case of a patient fall.</p> <p>Acoustics: sound attenuation level - High. Acoustic privacy required.</p> <p>Body protected electrical area.</p> <p>Additional design requirements:</p> <ul style="list-style-type: none"> - The shower floor must not have a raised hob - The entrance is to be flush with the adjoining floor - The door is to be fitted with escape hardware. 		
Amendment	13.03.2014 First issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200 mm		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
2530	Door protection			Protection plate to 900mm AFFL, minimum		
2529	Door protection			To door frame		Optional; to be decided at project level
9110	Doors	Solid Core	Paint	1 1/2 leaf		1200mm clear opening, outward opening, privacy latch, emergency release
2526	Floor finish	Vinyl	Non slip	Seamless, coved		Suitable for barefeet
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH		
3000	Wall finish	Paint	Acrylic, washable			

Department

Standard Components

Room Tag:

2320

Room Name

Ensuite - Bariatric

Room Code:

ENS-BA-SJ

ID	Fabric	Material	Finish	Specification	Selection	Remarks
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height		To wet areas; tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
5673	Chair: shower, bariatric	Furniture/ Fitting	3	1	Or commode chair or combined shower/commode chair; Bariatric capability
3400	Coathook	Metalwork	1	2	
4800	Curtain track: shower	Metalwork	1	1	Optional; depends on Infection Control Policy
5300	Curtain: shower	Furniture/ Fitting	3	1	Optional; depends on Infection Control Policy
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	Optional
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	To basin
6156	Dispenser: soap	Furniture/ Fitting	2	2	1 x basin; 1 x shower (optional)
6160	Dispenser: toilet paper	Furniture/ Fitting	1	1	Locate on drop down rail
8450	Grab rail: Shower	Metalwork	1	1	Combined with hand held shower; fixings to support bariatric capacity
8500	Grab rail: WC, hinged	Metalwork	1	2	Drop down rails both sides of WC; 1 x toilet paper dispenser; 1 x NC; fixings to support bariatric capacity
13700	Mirror	Metalwork	1	1	Over basin
20603	Soap/ shampoo holder: recessed	Furniture/ Fitting	1	1	
23700	Towel rail	Metalwork	1	1	With grab rail strength and fixings; fixings to support bariatric capacity
5824	Waste bin: paper	Furniture/ Fitting	3	1	To basin
19100	Waste bin: sanitary	Furniture/ Fitting	3	1	Optional; depends on Waste Management Policy

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	TW	Wm	WTap	Dns	Gas	Selection / Remarks
5603	Basin: ensuite	1	1			yes		yes	yes	yes	yes		With integral shelf for patient belongings or separate shelf; fixings to support bariatric capacity; Tapware: mixer, fixture mounted
39155	Patient lifter: ceiling mounted	1	1	yes									Track from bedroom; Optional, depends on Operational/ WH&S Policy
47400	Shower: hand-held	1	1			yes		yes	yes	yes	yes		Fixings to support bariatric capacity; Tapware: mixer, wall mounted, shower
5602	Toilet suite: bariatric	1	1			yes			yes	yes	yes		Concealed cistern optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
----	-------------	------------------	-----	---------------------

Department
Room Name

Standard Components
Ensuite - Bariatric

Room Tag: 2320
Room Code: ENS-BA-SJ

ID	Description	Service Category	Qty	Selection / Remarks
5019	Exhaust	HVAC		
5015	Ventilation	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		Sensor light optional
8080	Emergency call	Nurse Call	1	+ indicator button & light
8070	Patient call pendant	Nurse Call	1	Adjacent WC; Optional; or locate NC directly on drop down rail
8000	Patient to Staff call	Nurse Call	1	+ indicator button & light; may be located on drop down rail beside toilet
1951	Staff assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	1	