## Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

Print Date: 20 May 2014

Page 1 of 1

Issue No: 1

Issue Date: 1 Apr 2014

Department	Standard Components	Room Tag:	2600
Room Name	Laser Camera	Room Code:	LASC-SJ

**Net Room Area Briefed** 

3.0 M2

No of Rooms

1

**Subtotal of Briefed Area** 

3.00 M2

**Hours of Operation** 

24 Hours

Occupancy

N/A

Also covers these

Rooms

Description/ Special Requirements An open bay to accommodate a dry laser camera for printing of digital images, located within the Medical Imaging Unit. The Laser Camera area should have ready access to Imaging Procedures Rooms.

**Amendment** 

13.03.2014 First issue

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		

## Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	<b>V</b> mW	Тар	Dns	Gas	Selection / Remarks
7600	Camera: laser	3	1	ves	ves							

## **Services**

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9060	GPO: Special: for equipment	Power	1	Laser camera