Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Room Name	Standard Components Laundry - Patient	Room Tag: Room Code:	-		
Net Room Area Briefed	6.0 M2				
No of Rooms	1				
Subtotal of Briefed Area	6.00 M2				
Hours of Operation	24 Hours				
Occupancy	1 - 2				
Also covers these Rooms					
Description/ Special Requirements	Domestic style laundry for patient use. The laundry tub, domestic washing machine a		•		
Amendment	13.03.2014 First issue 24.03.2014 General revision				

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5007	Ceiling	Plasterboard	Paint	Bulkhead		
5021	Ceiling	Plasterboard	Paint, washable	Water resistant, flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, lockable
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		tiles also acceptable
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		Observation window, optional
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or coved tile skirting
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500AFFL		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	with inset laundry tub
1460	Bracket: wall	Metalwork	1	1	for dryer
1505	Cabinet: ironing board	Furniture/ Fitting	1	1	lockable, with integral ironing board
4340	Cupboard: adjustable shelves	Furniture/ Fitting	1	1	floor cupboard with adjustable shelves under laundary tub
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench
23956	Trolley: laundry, basket	Furniture/ Fitting	3	1	under bench



Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department	Standard Components	Room Tag:	2630
Room Name	Laundry - Patient	Room Code:	LAUN-PT-SJ

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	₩m₩	Тар	Dns	Gas	Selection / Remarks
18400	Dryer: tumble, domestic	3	1	yes								wall mounted
29200	Iron: electric	3	1	yes								inside cupboard
49400	Sink: laundry, single	1	1			yes	opt	opt	yes	yes		with overflow drain, warm water
60650	Washing machine: domestic	3	1	yes		yes	yes		yes	yes		heavy duty, warm water

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		extra steam/ heat extraction to room
5037	Special exhaust: dryer	HVAC	1	
4005	Cold water	Hydraulics	1	to washing machine
4033	Floor waste	Hydraulics	1	
4020	Warm water: outlet	Hydraulics	1	to washing machine
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	1	
9000	GPO: Single	Power	3	washer, dryer, ironing cabinet