

Department	Standard Components	Room Tag:	3070
Room Name	Mortuary - Viewing Room	Room Code:	MOR-VR-SJ
Net Room Area Briefed	8.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	8.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 trolley; Up to 3 family members; 1 staff member intermittently		
Also covers these Rooms			
Description/ Special Requirements	The Viewing Room is provided for bodies to be viewed by relatives/ friends. Bodies may be viewed through a window and optional access may be provided for relatives to directly view bodies. The Viewing Room will be located adjacent to the Mortuary Waiting Area.		
Amendment	14.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9110	Doors	Solid Core	Paint	1 1/2 leaf		1600mm clear opening, to Cool Store area, lockable, optional
9002	Doors	Solid Core/ Glass	Paint	Single leaf, half glazed		920mm clear opening, from Waiting area, optional, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		viewing window
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4045	Wall protection	Timber	Clear finish	Corner guards		to 900 AFFL; not required if room enclosed with walls & doors

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
4700	Curtain track: privacy screen	Metalwork	1	1	to bay & viewing window
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	
15460	Trolley: mortuary, hydraulic	Furniture/ Fitting	3	1	

Services

Department | Standard Components
Room Name | Mortuary - Viewing Room

Room Tag: 3070
Room Code: MOR-VR-SJ

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
6000	General fluorescent	Lighting		