

Department	Standard Components	Room Tag:	3270
Room Name	Office - Write-Up (Shared), 12m2	Room Code:	OFF-WIS-SJ
Net Room Area Briefed	12.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	12.00 M2		
Hours of Operation	24 Hours		
Occupancy	Up to 4		
Also covers these Rooms			
Description/ Special Requirements	A shared office located close to the Staff Station for staff to review and write up notes, view X-rays or digital imaging, enter patient data on computer, make telephone calls and store records.		
	Acoustics: Sound attenuation level - Medium; acoustic privacy required.		
Amendment	14.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		optional if door provided
9002	Doors	Solid Core/ Glass	Paint	Single leaf, half glazed		920mm clear opening, door optional
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		vinyl also acceptable
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		optional
949496	Skirting	Timber	Paint	150mmH x 20mm thick, nominal		or floor vinyl coved skirting if vinyl used
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	2	
1562	Cabinet: X-Ray slots	Furniture/ Fitting	1	2	under benches
2100	Chair: ergonomic, office	Furniture/ Fitting	3	4	
17360	Pinboard: fabric covered	Furniture/ Fitting	1	2	above benches
20000	Shelving unit: adjustable	Furniture/ Fitting	1	2	over benches, full length
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	2	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	W	H	T	W	m	W	Tap	Dns	Gas	Selection / Remarks
11400	Computer: PC & monitor	3	2	yes	yes	___	___	___	___	___	___	___	___	___	___	optional
41100	Printer: networked	3	1	yes	yes	___	___	___	___	___	___	___	___	___	___	optional
54510	Telephone: handset, standard	3	2	___	yes	___	___	___	___	___	___	___	___	___	___	

Department
Room Name

Standard Components
Office - Write-Up (Shared), 12m2

Room Tag: 3270
Room Code: OFF-WIS-SJ

ID	Description	Group	Qty	Ele	Data	Cd	WH	W	m	WT	Ap	Dns	Gas	Selection / Remarks
68900	Xray viewer: 4 screen	1	1	yes										recessed, optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	4	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelves
8040	Annunciator	Nurse Call		to be audible in this room
9001	GPO: Double	Power	9	2 per workstation + 1
9060	GPO: Special: for equipment	Power	1	Xray viewer