### Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

DepartmentStandard ComponentsRoom Tag:3500Room NamePatient Bay - ResuscitationRoom Code:PBTR-R-SJ

**Net Room Area Briefed** 

28.0 M2

No of Rooms

1

**Subtotal of Briefed Area** 

28.00 M2

Hours of Operation

24 Hours

Occupancy

1 patient; 4 - 5 staff

Also covers these Rooms

Description/ Special Requirements A Patient Bed Bay for assessment, resuscitation and treatment of patients with critical conditions, located within the Emergency Unit. The Bay may have partition side walls and a bench used for preparation and write-up. Resuscitation and diagnostic equipment should be located in close proximity which may include ventilator, cardiac pacemaking equipment and mobile X-ray machine.

Cardiac Protected electrical area

**Amendment** 

14.03.2014 - First Issue 24.03.2014 - General revision

#### **Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin & above bench
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		As required
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		As required

#### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	to services pendant
1050	Bench: laminate	Furniture/ Fitting	1	1	open under part
1470	Bracket: sharps	Furniture/ Fitting	2	1	on trolley
1950	Chair: ergonomic, high	Furniture/ Fitting	3	1	for staff use
4375	Cupboard: medication, lockable	Furniture/ Fitting	1	1	with drug safe
4410	Cupboard: under bench	Furniture/ Fitting	1	1	adjustable shelf
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, drug storage
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	

# Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current

Room Data Sheets

Department Standard Components Room Tag: 3500
Room Name Patient Bay - Resuscitation Room Code: PBTR-R-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
10700	IV hanger for ceiling track	Metalwork	1	1	optional, may be attached to pendant
11200	IV track: ceiling mounted	Metalwork	1	1	optional
12900	Louvred panel: for storage-bins	Metalwork	1	2	for storage, above bench
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	to services pendant
19060	Safe: dangerous drugs, small	Furniture/ Fitting	1	1	in cupboard
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over bench, storage
21755	Storage bins	Furniture/ Fitting	3	5	for storage on louvred panel
21950	Suction adapter	Furniture/ Fitting	3	2	to services pendant
22000	Suction bottle	Furniture/ Fitting	3	2	
18800	Trolley: resuscitation, adult	Furniture/ Fitting	3	1	
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	<b>/</b> mW	Тар	Dns	Gas	Selection / Remarks
3100	Basin: scrub, Type A	1	1			yes		yes	yes	yes		refer to BHWS-A (sim)
3725	Bed: emergency, electric	3	1	yes								
9700	Clock: analogue, electric	1	1	yes								
9800	Clock: time elapse	1	1	yes								beside analogue
11400	Computer: PC & monitor	3	1	yes	yes							to bench, optional
15500	Defibrillator	3	1	yes								on resuscitation trolley
15900	Diagnostic set: wall mounted	3	1	yes								
32650	Light: operating, single, 550 diam nominal	1	1	yes								
36050	Monitor: cardiac	3	1	yes	opt							on pendant
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								
46705	Services pendant: adj height, with arm	1	1	yes	yes							
54520	Telephone: handset, handsfree	3	1		yes							to bench
68800	Xray viewer: 3 screen	1	1	yes								recessed

### Services

ID	Description	Service Category	Qty	Selection / Remarks
1120	Monitor connection facilities and cabling	Communications	1	to services pendant, optional
1006	Voice / Data outlet: double	Communications	2	1-services pendant; 1-bench; 1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelves/ cupboards
7020	Medical Air (MA)	Medical Gases	2	services pendant
7010	Nitrous Oxide (N2O)	Medical Gases	1	optional

# Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current

**Room Data Sheets** 

DepartmentStandard ComponentsRoom Tag:3500Room NamePatient Bay - ResuscitationRoom Code:PBTR-R-SJ

ID	Description	Service Category	Qty	Selection / Remarks		
7000	Oxygen (O2)	Medical Gases	3	services pendant		
7070	Scavenge	Medical Gases	1	if N2O provided		
7040	Suction	Medical Gases	3	services pendant		
8080	Emergency call	Nurse Call	1	+ indicator button & light		
8005	Patient call handset	Nurse Call	1	call button on the handset		
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light		
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light		
9030	Cardiac protected	Power				
9015	GPO: Cleaner	Power	1			
9011	GPO: Emergency power, double	Power	1	for resus trolley		
9011	GPO: Emergency power, double	Power	2	to bench		
9010	GPO: Emergency power, single	Power	16	services pendant (2-UPS)		
9000	GPO: Single	Power	2	fridge, diagnostic set		
9060	GPO: Special: for equipment	Power	3	theatre light, clocks, XRV		

Provided by TAHPI for : Sharjah Domain

Issue No:1 Print Date: 20 May 2014 Issue Date: 1 Apr 2014 Page 3 of 3