

Department	Standard Components	Room Tag:	3770
Room Name	Scrub Up / Gowning, 6m2	Room Code:	SCRB-6-SJ
<b>Net Room Area Briefed</b>	6.0 M2		
<b>No of Rooms</b>	1		
<b>Subtotal of Briefed Area</b>	6.00 M2		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	Up to 2		
<b>Also covers these Rooms</b>			
<b>Description/ Special Requirements</b>	<p>The Scrub-up/ Gowning 6m2 provides for pre-operative scrubbing and gowning/ gloving, located adjacent to a Procedures Room or Imaging Room.</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> <li>- A minimum of 800mm is required between scrub stations</li> <li>- Taps to be non touch - automatically operated or foot operated</li> </ul>		
<b>Amendment</b>	13.03.2014 - First Issue		

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		to wet zone
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3010	Wall finish	Paint	Scrub resistant			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500AFFL		
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		

## Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
6164	Dispenser: scrub brush	Furniture/ Fitting	3	2	
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	2	
12300	Linen carrier: dirty, single	Furniture/ Fitting	3	1	
19810	Shelf: SS, over	Metalwork	1	1	over scrub trough
8390	Trolley: gowns	Furniture/ Fitting	3	1	optional

## Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	TW	N/m	WTap	Dns	Gas	Selection / Remarks
9700	Clock: analogue, electric	1	1	yes	—	—	—	—	—	—	—	—	
50000	Sink: scrub trough	1	1	—	—	yes	—	yes	yes	yes	—	—	auto/knee operated taps x 2

## Services

 <b>SHCC Guidelines</b>		Provided by TAHPI for : Sharjah Domain	Issue No: 1 Issue Date: 1 Apr 2014	Print Date: 20 May 2014 Page 1 of 2
------------------------------------------------------------------------------------------------------------	--	-------------------------------------------	---------------------------------------	----------------------------------------

Department  
Room Name

Standard Components  
Scrub Up / Gowning, 6m2

Room Tag: 3770  
Room Code: SCRB-6-SJ

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9000	GPO: Single	Power	1	for clock