#### **Sharjah Healthcare City - Health Facility Guidelines** Milestone: Current

**Room Data Sheets** 

**Standard Components** 3990 Department Room Tag: Specimen Reception/ Sort/ Preparation **Room Name Room Code:** SPREC-SJ

**Net Room Area Briefed** 

20.0 M2

No of Rooms

**Subtotal of Briefed Area** 

20.00 M2

**Hours of Operation** 

0800 Hours - 1800 or 2000 hours

Occupancy

Up to 4 staff members, 3 seated workstations

Also covers these

Rooms

Description/ **Special Requirements** 

A Reception area where specimens for analysis are received, sorted and held temporarily before despatch into laboratory areas.

Additional Design Requirements:

- Security shutters or glazing may be required

**Amendment** 

13.03.2014 - First Issue

### **Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
5007	Ceiling	Plasterboard	Paint	Bulkhead		optional
6025	Cornice	Aluminium	Powdercoat	shadow line		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, lockable
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		to front reception area
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		to sort/ preparation area
949496	Skirting	Timber	Paint	150mmH x 20mm thick, nominal		to front reception area
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		to sort/ preparation area
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin & sorting bench, tiles also acceptable
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		

## Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	sorting bench at 900mm high
1110	Bench: laminate, writing	Furniture/ Fitting	1	1	at 720mm high
1110	Bench: laminate, writing	Furniture/ Fitting	1	1	at 900mm high
4410	Cupboard: under bench	Furniture/ Fitting	1	1	under part bench
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over part workstation bench
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin

Issue Date: 1 Apr 2014

# **Sharjah Healthcare City - Health Facility Guidelines**

**Room Data Sheets** 

Milestone: Current

DepartmentStandard ComponentsRoom Tag:3990Room NameSpecimen Reception/ Sort/ PreparationRoom Code:SPREC-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
11465	Keyboard shelf: drop down	Furniture/ Fitting	1	3	optional
17250	Pedestal drawer unit: mobile, 660mmH	Furniture/ Fitting	3	2	under bench
17360	Pinboard: fabric covered	Furniture/ Fitting	1	2	to upstand of reception desk and over workstation bench
18550	Reception desk: laminate/ timber	Furniture/ Fitting	1	1	with resinate/ laminate countertop
18930	Roller shutter, manual	Metalwork	1	1	optional, may also use safety glass or 'Perspex/ Lexan' materials
20000	Shelving unit: adjustable	Furniture/ Fitting	1	2	over sorting/ prepartion area benches
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	2	1 to basin

# Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	<b>%</b> mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		
8900	Centrifuge	3	1	yes								
11400	Computer: PC & monitor	3	3	yes	yes							flat screen
27900	Incubator: laboratory	3	1	yes								optional
41100	Printer: networked	3	1	yes	yes							
43500	Refrigerator	3	1	yes								specimen holding
54510	Telephone: handset, standard	3	3		yes							

### **Services**

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	5	
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6030	Special: downlights	Lighting		to bulkhead, if provided
6055	Special: task light, built in	Lighting		under O/H joinery
9001	GPO: Double	Power	9	
9000	GPO: Single	Power	1	refrigerator
10005	Duress alarm	Security	1	

SHCC Guidelines

Provided by TAHPI for : Sharjah Domain

Issue No:1 Print Date: 20 May 2014 Issue Date: 1 Apr 2014 Page 2 of 2