Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

DepartmentStandard ComponentsRoom Tag:4630Room NameTreatment Bay - ChemotherapyRoom Code:TRMT-CHE-SJ

Net Room Area Briefed

10.0 M2

No of Rooms

l 1

Subtotal of Briefed Area

10.00 M2

Hours of Operation

0800 Hours to 1800 Hours, daily

Occupancy

1 patient, 1support person, 1 staff assisting

Also covers these

Rooms Remarks

If bed is used, bay will need to increase to 12m2 for sufficient clearances

to the sides of the bed.

Description/ Special Requirements The Treatment Bay - Chemotherapy is used for day treatment of patients undergoing cytotoxic treatments. A staff handwashing basin will be provided for each 4 bays (refer to Bay-Handwashing Type B for basin).

Body Protected electrical area

Amendment

13.03.2014 - First Issue 24.03.2014 - General revision

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin, tiles also acceptable
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
7001	Windows					Desirable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	1 between 2 bays
1250	Blind: Venetian	Metalwork	3	1	to external windows
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	1 between 2 bays
23400	Bracket: television, ceiling	Metalwork	1	1	to each bay
2200	Chair: recliner	Furniture/ Fitting	3	1	or patient bed
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	to basin
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin

Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current

Room Data Sheets

Print Date: 20 May 2014

Page 2 of 2

Issue No: 1

Issue Date: 1 Apr 2014

DepartmentStandard ComponentsRoom Tag:4630Room NameTreatment Bay - ChemotherapyRoom Code:TRMT-CHE-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	1 between 2 bays
19705	Sharps bin: mobile trolley	Furniture/ Fitting	3	1	cytotoxic
19800	Shelf: laminate	Furniture/ Fitting	1	1	for equipment
21950	Suction adapter	Furniture/ Fitting	3	1	1 between 2 bays
22000	Suction bottle	Furniture/ Fitting	3	1	1 between 2 bays
16200	Table: overbed	Furniture/ Fitting	3	1	
6610	Trolley: dressing, 1 drawer	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	%mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		refer to BHWS-B-U (sim)
31750	Light: examination, mobile	3	1	yes								where bed trolley is used instead of recliner
54510	Telephone: handset, standard	3	1		yes							optional
54550	Television: 34 cm	3	1	yes								

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 per bay
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6050	Special: reading	Lighting		
7020	Medical Air (MA)	Medical Gases	1	1 per 2 bays
7000	Oxygen (O2)	Medical Gases	1	1 per 2 bays
7040	Suction	Medical Gases	1	1 per 2 bays
8080	Emergency call	Nurse Call	1	+ indicator button & light; shared for 4 bays
8005	Patient call handset	Nurse Call	1	call button on the handset, 1 per bay
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light, 1 per bay
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light, 1 per bay
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	per room as required
9010	GPO: Emergency power, single	Power	1	to patient services panel
9000	GPO: Single	Power	3	to patient services panel
9060	GPO: Special: for equipment	Power	1	TV