Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Standard Components Department Room Tag: 4660 **Treatment Room - Paediatrics Room Name Room Code:** TRMT-P-SJ

Net Room Area Briefed

14.0 M2

No of Rooms

Subtotal of Briefed Area

14.00 M2

Hours of Operation

24 Hours

Occupancy

1 patient; 1-2 staff

Also covers these Rooms

Description/ **Special Requirements** The Treatment Room - Paediatrics provides a controlled environment, privacy and facilities for carrying out consultations, examinations and treatments which may include wound dressings, for paediatric patients.

Acoustics: Sound attenuation level - high; Acoustic privacy is required.

Body Protected electrical area

Amendment

13.03.2014 - First Issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening; lockable; observation panel optional
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, to Clean Utility, optional
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		

Fittings and Furniture (FF)

Description	Category	Group	Qty	Selection / Remarks
Air flowmeter	Furniture/ Fitting	Furniture/ Fitting 3		to services panel
Bench: laminate	Furniture/ Fitting	1	1	optional
Bracket: sharps	Furniture/ Fitting	2	1	on trolley
Bracket: suction bottle	Furniture/ Fitting	2	1	
Clock: battery operated	Furniture/ Fitting	3	1	
Cupboard: under bench	Furniture/ Fitting	1	1	adjustable shelf, optional
	Air flowmeter Bench: laminate Bracket: sharps Bracket: suction bottle Clock: battery operated	Air flowmeter Furniture/ Fitting Bench: laminate Furniture/ Fitting Bracket: sharps Furniture/ Fitting Bracket: suction bottle Furniture/ Fitting Clock: battery operated Furniture/ Fitting	Air flowmeter Furniture/ Fitting 3 Bench: laminate Furniture/ Fitting 1 Bracket: sharps Furniture/ Fitting 2 Bracket: suction bottle Furniture/ Fitting 2 Clock: battery operated Furniture/ Fitting 3	Air flowmeter Furniture/ Fitting 3 1 Bench: laminate Furniture/ Fitting 1 1 Bracket: sharps Furniture/ Fitting 2 1 Bracket: suction bottle Furniture/ Fitting 2 1 Clock: battery operated Furniture/ Fitting 3 1

Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current **Room Data Sheets**

Standard Components Department Room Tag: 4660 **Treatment Room - Paediatrics Room Name** Room Code: TRMT-P-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, adjustable shelf, optional
4600	Curtain track: bed screen	Metalwork	1	1	to door opening
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	3 compartments
6157	Dispenser: medicated hand gel	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12900	Louvred panel: for storage-bins	Metalwork	1	2	over bench, optional
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	to services panel
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
21755	Storage bins	Furniture/ Fitting	3	5	for louvred panels, optional
21950	Suction adapter	Furniture/ Fitting	3	1	to services panel
6600	Trolley: dressing	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	//mW	Тар	Dns	Gas	Selection / Remarks
3100	Basin: scrub, Type A	1	1			yes		yes	yes	yes		refer to BHWS-A (sim)
3740	Bed: paediatric, electric	3	1	yes								
31700	Light: examination, ceiling	1	1	yes								
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
54510	Telephone: handset, standard	3	1		yes							to bench, optional
68700	Xray viewer: 2 screen	1	1	yes								optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
7020	Medical Air (MA)	Medical Gases	1	
7010	Nitrous Oxide (N2O)	Medical Gases	1	
7000	Oxygen (O2)	Medical Gases	2	
7070	Scavenge	Medical Gases	1	
7040	Suction	Medical Gases	1	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	1	to bench
9010	GPO: Emergency power, single	Power	6	to patient services panel
9000	GPO: Single	Power	6	to patient services panel
9000	GPO: Single	Power	2	XRV, fridge

Issue No: 1

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Standard Components Room Tag: 4660

Room Name Treatment Room - Paediatrics Room Code: TRMT-P-SJ

ID	Description	Service Category		Selection / Remarks		
9060	GPO: Special: for equipment	Power	1	exam light		
11000	Wall panel	Services Panels	1			