Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Room Name	Standard Components Treatment Room	Room Tag: Room Code:	4650 TRMT-SJ					
Net Room Area Briefed	14.0 M2							
No of Rooms	1							
Subtotal of Briefed Area	14.00 M2							
Hours of Operation	24 Hours							
Occupancy	1 patient; 1-2 staff							
Also covers these Rooms								
Description/ Special Requirements	· facilities for compliant out concultations, avaningtions, and tractments which							
	Acoustics: Sound attenuation level - h	nigh; Acoustic privacy is require	ed.					
	Body Protected electrical area							
Amendment	13.03.2014 - First Issue							

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening; lockable; observation panel optional
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, to Clean Utility, optional
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	to services panel
700	Bed: inpatient, manual	Furniture/ Fitting	3	1	
1050	Bench: laminate	Furniture/ Fitting	1	1	optional
1470	Bracket: sharps	Furniture/ Fitting	2	1	on trolley
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	
3350	Clock: battery operated	Furniture/ Fitting	3	1	

	Provided by TAHPI for :	Issue No: 1	Print Date:	20 May 2014
SHCC Guidelines	Sharjah Domain	Issue Date: 1 Apr 2014	4	Page 1 of 2

Sharjah Healthcare City - Health Facility Guidelines

Room Data Sheets

Milestone: Current

	Department	Stand	ard Components			Room Tag:	4650
	Room Name	Treatn	nent Room			Room Code:	TRMT-SJ
ID	Description		Category	Group	Qty	Selection / Remarks	
4410	Cupboard: under bench		Furniture/ Fitting	1	1	adjustable shelf, optional	
4470	Cupboard: wall mounted, loc	kable	Furniture/ Fitting	1	1	over bench, adjustable sh	elf, optional
4600	Curtain track: bed screen		Metalwork	1	1	to door opening	
5000	Curtain: bed screen		Furniture/ Fitting	3	1		
6152	Dispenser: disposable glove		Furniture/ Fitting	2	1	3 compartments	
6157	Dispenser: medicated hand	gel	Furniture/ Fitting	2	1		
6154	Dispenser: paper/ hand towe	el	Furniture/ Fitting	2	1	to basin	
6156	Dispenser: soap		Furniture/ Fitting	2	1	to basin	
6158	Dispenser: soap antiseptic		Furniture/ Fitting	2	1	to basin	
12900	Louvred panel: for storage-b	ins	Metalwork	1	2	over bench, optional	
16250	Oxygen flowmeter		Furniture/ Fitting	3	2	to services panel	
19700	Sharps bin		Furniture/ Fitting	3	1	on trolley	
21755	Storage bins		Furniture/ Fitting	3	5	for louvred panels, optiona	al
21950	Suction adapter		Furniture/ Fitting	3	1	to services panel	
6600	Trolley: dressing		Furniture/ Fitting	3	1		
24100	Waste bin: paper, 20 Litre		Furniture/ Fitting	3	1	to basin	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	VmW	Тар	Dns	Gas	Selection / Remarks
3100	Basin: scrub, Type A	1	1			yes		yes	yes	yes		refer to BHWS-A (sim)
31700	Light: examination, ceiling	1	1	yes								
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
54510	Telephone: handset, standard	3	1		yes							to bench, optional
68700	Xray viewer: 2 screen	1	1	yes								optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
7020	Medical Air (MA)	Medical Gases	1	
7000	Oxygen (O2)	Medical Gases	2	
7040	Suction	Medical Gases	1	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	1	to bench
9010	GPO: Emergency power, single	Power	6	to patient services panel
9000	GPO: Single	Power	6	to patient services panel
9000	GPO: Single	Power	2	XRV, fridge
9060	GPO: Special: for equipment	Power	1	exam light
11000	Wall panel	Services Panels	1	

Issue No: 1 Print Date: 20 May 2014 Provided by TAHPI for : SHCC Guidelines Sharjah Domain Page 2 of 2 Issue Date: 1 Apr 2014