

Department	Standard Components	Room Tag:	4680
Room Name	Ultrasound	Room Code:	ULTR-SJ
Net Room Area Briefed	14.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	14.00 M2		
Hours of Operation	Available 24 Hours		
Occupancy	1 patient with up to 1 support person; 1-2 staff		
Also covers these Rooms			
Description/ Special Requirements	Room for diagnostic ultrasound procedures, located close to patient toilet and change rooms. The room will require access for patients on hospital beds.		
	Acoustics: Acoustic privacy required		
	Body Protected electrical area		
Amendment	13.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		flush set plasterboard ceiling also acceptable
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	at 1000H, open under part
23400	Bracket: television, ceiling	Metalwork	1	1	
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
2600	Chair: visitor, office	Furniture/ Fitting	3	2	optional
3350	Clock: battery operated	Furniture/ Fitting	3	1	
3400	Coathook	Metalwork	1	1	
4345	Cupboard: sliding doors, adj shelves	Furniture/ Fitting	3	1	lockable, optional
4410	Cupboard: under bench	Furniture/ Fitting	1	1	under part bench, adjustable shelf
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench, adjustable shelves

Department
Room Name

Standard Components
Ultrasound

Room Tag: 4680
Room Code: ULTR-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
4700	Curtain track: privacy screen	Metalwork	1	1	to entry door
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to entry door
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
7500	Examination couch	Furniture/ Fitting	3	1	mobile
8100	Footstool	Furniture/ Fitting	3	1	
18445	Rack: scanhead storage	Furniture/ Fitting	3	1	
23950	Trolley	Furniture/ Fitting	3	1	under bench
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	TW	Nm	WTap	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes	yes		refer to BHWS-B (sim)
57800	IMG: Ultrasound scanning unit	3	1	yes									
54510	Telephone: handset, standard	3	1		yes								
54550	Television: 34 cm	3	1	yes									ceiling mounted

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	2	
5000	Airconditioning	HVAC		
6110	Downlights: dimmable	Lighting		
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	as required
9001	GPO: Double	Power	3	2 - staff workstation; 1- bench
9000	GPO: Single	Power	2	exam couch
9060	GPO: Special: for equipment	Power	1	Ultrasound machine